

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County	Fraction	Section number	Township number	Range number
SUMNER			1/4 NW 1/4 NE 1/4	22	T 31 S R	2E E/W
2. Distance and direction from nearest town or city:		3. Owner of well:		Wm. Earl McGinnis		
Street address of well location if in city:		Belle Plaine, Ks.,		524 S. Crestway		
3 S., 2 1/2 E. on		City, state, zip code:		Wichita, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 11 in. Completion date		
N		the S. side of the road.		Well depth 63 ft. 7-21-78		
W		Belle Plaine, Ks.		7. Cable tool X Rotary Driven Dug		
E				Hollow rod Jetted Bored Reverse rotary		
S				8. Use: Domestic Public supply Industry		
1 Mile				X Irrigation Air conditioning Stock		
				Lawn Oil field water Other		
				9. Casing: Material PVC Height: Above or below		
				Threaded Welded Surface 12 in.		
				RMP PVC X Weight 3.96 lbs./ft.		
				Dia. 6 in. to 63 ft. depth Wall thickness: inches or		
				Dia. in. to ft. depth Gauge No. 316		
5. Type and color of material		From	To	10. Screen: Manufacturer's name		
Sandy Topsoil	0	2	PVC NSF Approved 200 PSI			
Brown Clay	2	10	Type PVC 200 PSI Dia. 6"			
Fine Sand	10	25	Slot size .06 Length 25'			
Coarse Sand	25	35	Set between 38 ft. and 63 ft.			
Gray Clay	35	38	Gravel pack? yes Size range of material 1/4-1/8"			
Coarse Sand	38	63	11. Static water level: mo./day/yr.			
			10 ft. below land surface Date 7-21-78			
			12. Pumping level below land surfaces:			
			ft. after hrs. pumping g.p.m.			
			ft. after hrs. pumping g.p.m.			
			Estimated maximum yield g.p.m.			
			13. Water sample submitted: mo./day/yr.			
			Yes No Date			
			14. Well head completion: capped			
			Pitless adapter 12 Inches above grade			
			15. Well grouted? yes 1-2 Fine Sand Mix			
			With: Neat cement Bentonite X Concrete			
			Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination:			
			ft. Direction Type NONE			
			Well disinfected upon completion? X Yes No			
			17. Pump: X Not installed			
			Manufacturer's name			
			Model number HP Volts			
			Length of drop pipe ft. capacity g.p.m.			
			Type:			
			Submersible Turbine			
			Jet Reciprocating			
			Centrifugal Other			
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography:		Flat Ground		This well was drilled under my jurisdiction and this report		
Hill		No apparent source for contamination.		is true to the best of my knowledge and belief.		
Slope				Harp Well & Pump 236		
Upland				Business name License No.		
Valley				Address Wichita, Kansas 67209		
				Signed M. Arnold		
				Authorized representative Date 7-25-78		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5