


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SUMNER	Fraction 1/4 NE 1/4 NW 1/4	Section number 28	Township number T 31 S	Range number R 2E E/W
2. Distance and direction from nearest town or city:		2 miles E. of Belle Plaine, Ks.		3. Owner of well: Curtis Dunn		
Street address of well location if in city:		3 miles So., 1 E.		R.R. or street: R. #1		
				City, state, zip code: Belle Plaine, Kansas		
4. Locate with "X" in section below:		Sketch map: 1 So., and 1/2 mile E., on the So. side of the road. Belle Plaine, Kansas		6. Bore hole dia. 11 in. Completion date 7-17-78 Well depth 58 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Topsoil		0		3		9. Casing: Material Styrene Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> g1 Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 12 lbs./ft. Dia. 5 in. to 58 ft. depth Wall Thickness: inches or Dia. 5 in. to 58 ft. depth gage No. .200
Clay		3		10		10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/groove .06 Length 30' Set between 28 ft. and 58 ft. Gravel pack? yes Size range of material 1/4-1/8"
Fine Sand & Clay		10		25		11. Static water level: 15 ft. below land surface Date 7-17-78 mo./day/yr.
Medium Sand		25		58		12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
						13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____
						14. Well head completion: 12 capped ____ Pitless adapter ____ Inches above grade
						15. Well grouted? yes 1-2 Fine Sand Mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40' ft. to 14 ft.
						16. Nearest source of possible contamination: ft. ____ Direction ____ Type NONE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography: ____ Hill ____ Slope ____ Upland ____ Valley		Flat Ground No apparent source for contamination.		Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 9-21-78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5