

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Labette CRAWFORD	Township name	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 16	Town number 31 30 S.	Range number 21 E.
Distance and direction from nearest town or city: 5 MILES WEST & 1 MILE SOUTH OF			3 Owner of well: CRAWFORD COUNTY RURAL WATER DISTRICT No. 6			
Street address of well location if in city: MC CUNE, KS.			Address: ROUTE 3- MC CUNE, KS.			
Locate with "X" in section below: NEOSHO RIVER			Sketch map:		4 Well depth: 33 ft. Date of completion 9-9-76 Well diameter 30 in.	
					5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					6 Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
2 WELL No. 6			Type and color of material		7 Casing: Material STEEL Height: above /below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 36 in. Diam. 8 in. Weight 25 lbs./ft. 8 in. to 33 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth	
			From To		8 Screen: Manufacturer LAYNE & BOWLER Type SHUTTER Dia. 8" Slot/gauze .125 Length 5'-0" Set between 26 ft. and 31 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4 x 1/8	
BROWN SILTY CLAY			0' 12'		9 Static water level: 24'-4" ft. below land surface Date 9-9-76	
GRAY CLAY			12' 16'		10 Pumping level below land surfaces: 29'-5 1/2" ft. after 1 hrs. pumping 20 g.p.m. 29'-10 1/2" ft. after 5 hrs. pumping 20 g.p.m. Estimated maximum yield 20 g.p.m.	
BLUE CLAY			16' 24'		11 Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 9-1-76	
MEDIUM TO COARSE SAND & GRAVEL			24' 31'		12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
SHALE, HARD			31' 33'		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 20 ft. to 18 ft.	
					14 Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation APPROX. 840'					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. LAYNE-WESTERN Co. 149 Business name License No. Address 100 W 3rd St - K.C. Mo. Signed W. D. [Signature] Date 9/24/76 Authorized representative	

315 21E 16 NW SE SE