

OFFICE USE ONLY

T

33

R

10

EW

SEC

NE 1/4 NW 1/4 SW 1/4

1 LOCATION OF WATER WELL
 County: Montgomery Fraction: NE 1/4 NW 1/4 SW 1/4 Section Number: 3 Township Number: T 33 S Range Number: R 16 EW
 Distance and direction from nearest town or city? Independence, Ks. 3 mi. E of 10th St. S. on Poor Farm Rd. 1/2 M. N. Street address of well if located within city?

2 WATER WELL OWNER: James H. Hare
 RR#, St. Address, Box #: R. R. 2; Box 197B Board of Agriculture, Division of Water Resources
 City, State, ZIP Code: Independence, Ks. 67301 Application Number:

3 DEPTH OF COMPLETED WELL: 145 ft. Bore Hole Diameter: 10 in. to 19 ft., and 6 1/2 in. to 145 ft.
 Well Water to be used as:
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 7 Lawn and garden only 10 Observation well
 Well's static water level: 90 ft. below land surface measured on _____ month _____ day _____ year
 Pump Test Data: Well water was _____ ft. after _____ hours pumping _____ gpm
 Est. Yield: _____ gpm Well water was _____ ft. after _____ hours pumping _____ gpm

4 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued _____ Clamped _____
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) _____ Welded _____
 7 Fiberglass _____ Threaded _____
 Blank casing dia: 6 in. to 19 ft., Dia _____ in. to _____ ft., Dia _____ in. to _____ ft.
 Casing height above land surface: 16 in., weight _____ lbs./ft. Wall thickness or gauge No: 3/8"
TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify) _____
 12 None used (open hole)
 Screen or Perforation Openings Are:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
 7 Torch cut 10 Other (specify) _____
 Screen-Perforation Dia: _____ in. to _____ ft., Dia _____ in. to _____ ft., Dia _____ in. to _____ ft.
 Screen-Perforated Intervals: From _____ ft. to _____ ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.
 Gravel Pack Intervals: From _____ ft. to _____ ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other _____
 Grouted Intervals: From 2 ft. to 19 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.
 What is the nearest source of possible contamination? _____
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well
 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)
 13 Watertight sewer lines
 Direction from well: South How many feet: 300 ft. Water Well Disinfected? Yes X No _____
 Was a chemical/bacteriological sample submitted to Department? Yes _____ No X If yes, date sample was submitted _____ month _____ day _____ year Pump Installed? Yes _____ No X
 If Yes: Pump Manufacturer's name _____ Model No. _____ HP _____ Volts _____
 Depth of Pump Intake _____ ft. Pumps Capacity rated at _____ gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other _____

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on _____ Sept _____ month _____ 7th _____ day _____ 1984 _____ year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. _____ 403
 This Water Well Record was completed on _____ 9-Sept. _____ month _____ 10th _____ day _____ 1984 _____ year under the business name of V W & B Drilling Co. by (signature) William J. Billman

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	1	<u>01</u> Top Soil	140	145	Gray Shale
1	7	<u>730</u> Churt & Yellow Clay			
7	38	<u>20</u> Limestone			
38	60	<u>19</u> Gray Shale			
60	69	<u>20</u> Limestone			
69	73	<u>19</u> Gray Shale			
73	92	<u>24</u> Water Sand & Shale			
92	97	<u>20</u> Siltstone			
97	134	<u>19</u> Gray Shale			
134	140	<u>20</u> Limestone			

ELEVATION: _____

Depth(s) Groundwater Encountered 1. 73 ft. 2. 97 ft. 3. _____ ft. 4. _____ ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

DP