

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Cowley	Fraction SW SE NE 1/4 NW 1/4 NW 1/4	Section number 7	Township number T 34 33 S	Range number R 4 W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: LESTER J. PRIEST R.R. or street: 3 City, state, zip code: WINFIELD, KANSAS 67156			
4. Locate with "X" in section below: Sketch map: No 2 WELL			6. Bore hole dia. 3 1/2" in. Completion date 5-12-77 Well depth 57 ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia 12 in. to 45 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1219			
10. Screen: Manufacturer's name DOERR Type 10 MILD STEEL Slot/gauze 1/4" Length 12' Set between 45' ft. and 57' ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material COARSE SAND			11. Static water level: <input type="checkbox"/> mo./day/yr. 35 ft. below land surface Date 5-16-77			
12. Pumping level below land surfaces: 45' ft. after 4 hrs. pumping 400 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 550 g.p.m.			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <input type="checkbox"/>			
14. Well head completion: <input type="checkbox"/> Pitless adapter 12" inches above grade			15. Well grouted? NO <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 25' ft. MNC			
16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type NONE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name WESTERN LAND ROLLER Model number <input type="checkbox"/> HP 20 Volts 480 Length of drop pipe 56' ft. capacity 300 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. HUNT DRILLING Co 249 Business name License No. Address ARKANSAS CITY, KS 64601 Signed Walter R Hunt Date 6-74 Authorized representative			
19. Remarks: Companion well to No 1 to supply irrigation water for center pivot system						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 33 R 4 W
 Sec 7 SW SE NW
 1/4 1/4 1/4