

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County COWLEY Fraction SE 1/4 SE 1/4 SE 1/4 Section number 19 Township number T 33 Range number S R 4 E																			
2. Distance and direction from nearest town or city: 4 mi S 1 mi W of WINFIELD, KS Street address of well location if in city: _____																			
3. Owner of well: GEORGE JORDAN R.R. or street: R#2 City, state, zip code: WINFIELD KANSAS 67156																			
4. Locate with "X" in section below: Sketch map: SEC 19																			
6. Bore hole dia. 9" in. Completion date 12-5-79 Well depth 44 ft.																			
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary																			
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																			
9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 30 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 4" in. to 36 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1214																			
5. Type and color of material																			
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:80%;"></th> <th style="width:10%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr> <td>Soil & Clay</td> <td>1'</td> <td>25'</td> </tr> <tr> <td>Fine Sand & Clay</td> <td>26'</td> <td>30'</td> </tr> <tr> <td>Med. Sand - some clay</td> <td>31'</td> <td>40'</td> </tr> <tr> <td>Coarse Sand</td> <td>41'</td> <td>44'</td> </tr> <tr> <td>Shale</td> <td></td> <td>44 1/2'</td> </tr> </tbody> </table>			From	To	Soil & Clay	1'	25'	Fine Sand & Clay	26'	30'	Med. Sand - some clay	31'	40'	Coarse Sand	41'	44'	Shale		44 1/2'
	From	To																	
Soil & Clay	1'	25'																	
Fine Sand & Clay	26'	30'																	
Med. Sand - some clay	31'	40'																	
Coarse Sand	41'	44'																	
Shale		44 1/2'																	
10. Screen: Manufacturer's name RUTH-BERRY Type EPOXY-SAND Dia. 4" Slot/gauze 4" Length 4' Set between 36' ft. and 40' ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material COARSE SAND																			
11. Static water level: _____ mo./day/yr. 24 ft. below land surface Date 12-5-79																			
12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.																			
13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____																			
14. Well head completion: <input type="checkbox"/> Pitless adapter 30 Inches above grade																			
15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 1 ft. to 20 ft.																			
16. Nearest source of possible contamination: ft. 100' Direction East Type SEPTIC <input checked="" type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																			
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																			
(Use a second sheet if needed)																			
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Owner will install pump which will be inside a room he is building on to his residence.																		
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. HUNT DRILLING Co 249 Business name _____ License No. _____ Address R#2 ARKANSAS CITY, KS Signed Walter J. Hunt Date 12-28-79 Authorized representative																			

T 33 - 40
 R 4
 W E
 Sec 19
 1/4 SE 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5