

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sumner	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 33	Township number T 34	Range number S R 2	E 1/4
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Edward L. Broyles R.R. or street: RR #1 City, state, zip code: Geuda Springs, Kansas 67051				
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 7 in. Completion date 6-15-76 Well depth 40 ft.		
					7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other Fish ponds	
Topsoil				0	1	9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded glue Surface 18 " in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 4 "	
Clay - Brown				1	12	10. Screen: Manufacturer's name _____ Type PVC Dia. 5 " Slot/gauze .030 Length 10 ' Set between 27 ft. and 37 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/2 to 3/4	
Clay - Sandy, grayish Brown				12	20	11. Static water level: _____ mo./day/yr. 20 ft. below land surface Date 6-15-76	
Sand - Fine to med grain				20	24	12. Pumping level below land surfaces: 20 ft. after 1 hrs. pumping 40 g.p.m. 20 ft. after 24 hrs. pumping 40 g.p.m. Estimated maximum yield 170 g.p.m.	
Sand - med to coarse grain				24	33	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Sand - coarse to v. coarse grain				33	37	14. Well head completion: <input type="checkbox"/> Pitless adapter 18 Inches above grade	
Limestone				37	40	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 20 ft.	
(Use a second sheet if needed)						16. Nearest source of possible contamination: ft. 500 Direction East Type gas Tanks Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
18. Elevation:		19. Remarks:			17. Pump: Not installed Manufacturer's name Jacuzzi Model number _____ HP 2 Volts 220 Length of drop pipe 37 ft. capacity 40 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Drilled with my own Equipment Business name _____ License No. _____ Address _____ Signed Edward L. Broyles Date 6-15-76 Authorized representative		

T 34
 R 2
 E 1/4
 Sec 33
 NE 1/4 NE 1/4 NE 1/4