

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Cowley	Fraction 1/4 SW 1/4 SW 1/4	Section number 26	Township number T 34 S	Range number R 3 E E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
1 West of Ark City, Kansas 1/4 North of Hyway 160, then 1/4 East. Ark City, Kansas			Tome Haynes R. R. #1 Arkansas, Kansas			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			6. Bore hole dia. 11 in. Completion date _____ Well depth 50 ft. 7-29-77 7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material styrene Height: Above of below Threaded _____ Welded g1 Surface _____ 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 50 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 200			
5. Type and color of material			From	To		
Topsoil			0	3	10. Screen: Manufacturer's name _____ Sunflower Plastic	
Clay			3	10	Type styrene Dia. 5 " Slot/gauge 06 Length 25' Set between 25 ft. and 50 ft. _____ ft. and _____ ft.	
Brown Shale			10	28	Gravel pack? yes Size range of material 1/4-1/8"	
Gray Shale			28	50	11. Static water level: _____ mo./day/yr. 23 ft. below land surface Date 7-29-77	
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. Yes _____ No _____ Date _____	
					14. Well head completion: _____ capped _____ Pitless adapter 12 inches above grade	
					15. Well grouted? yes 1-2 fine sand mix With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete 34 Depth: From 40 ft. to 14 ft. 3	
					16. Nearest source of possible contamination: Septic ft. 500 Direction West Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No	
					17. Pump: <input checked="" type="checkbox"/> Nat installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other	
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. _____ Address _____ Signed M. Arnold Date 8-31-77 Authorized representative			
Topography: _____ Hill <input checked="" type="checkbox"/> Slope _____ Upland _____ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5