

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County: MONTGOMERY	Fraction: NE 1/4 NE 1/4 1/4	Section number: 1	Township number: T 35 S R 15 E	Range number: 15	
2. Distance and direction from nearest town or city:	3 MILE EAST OF TYRO, KANS ON HWY 106		3. Owner of well: NORMAN HEDRICK	R.R. or street: _____ City, state, zip code: COFFEYVILLE KANS.		
4. Locate with "X" in section below:	Sketch map: NO HOUSE			6. Bore hole dia. 9 in. Completion date 8/18/78 Well depth 120 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			From	To	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 12 in. RMP 50# PVC 40 Weight _____ lbs./ft. Dia. 6 in. to 20 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 0.320	
CLAY			0	7	10. Screen: Manufacturer's name _____ Type _____ Dia. _____ Slot/gauze _____ Length _____ Set between _____ ft. and _____ ft. _____ ft. and _____ ft. Gravel pack? _____ Size range of material _____	
SAND ROCK			7	25	11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 8/18/78	
GRAY SHALE			25	75	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 3 g.p.m.	
SANDY SHALE			75	93	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
SAND			93	120	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade	
					15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Moore Drilling Co. 345 Business name _____ License No. _____ Address Clearing, Kansas Signed Delbert Moore Date 8/18/78 Authorized representative	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: CUSTOMER TO INSTALL CONCRETE SLAB. HE KNOWS THIS IS A STATE REGULATION				<div style="position: absolute; right: -50px; top: 50%; transform: translateY(-50%); font-size: 2em; font-weight: bold;">35 150 1-1 NE NE</div>	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5