

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1. Location of well:	County Cowley	Township name Silverdale	Fraction SE-SE-SE	Section number 12	Town number 35-S	Range number S-E
Distance and direction from nearest town or city: 3 miles west of Maple City, 3 miles south.			3 Owner of well: Jim Warren Address: Maple City, Kansas 67102			
Locate with "X" in section below: N W E S 1 Mile			Sketch map: abandoned railroad cattle Pen slope $\square \rightarrow$ well Pasture Grass			4 Well depth: 74 ft. Date of completion 9-17-76 Well diameter 10 in.
2 Type and color of material			From	To	5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Clean out + Rework -			0	74	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> Stock well	
Core in - 10 FT Blue Shale in bottom of well.					7 Casing: #200 Material Plastic Height: above/below <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface 1 1/4 in. Diam. 6 in. to 7 1/4 ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 6 in. to 7 1/4 ft. depth!	
Well has 4 ft cement slab 12" thick surrounding hole with 20 FT Galv. casing from 0' to 20' in the line.					8 Screen: Casing Perforated Manufacturer Bottom 10 FT. Type _____ Dia. 6" Slot/gauze _____ Length _____ Set between 0 ft. and 7 1/4 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 5/8"	
					9 Static water level: 40 ft. below land surface Date 9-17-76	
					10 Pumping level below land surfaces: none _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1 g.p.m.	
					11 Water sample submitted: NA <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					12 Well head completion: NA <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> See below Depth: From 0 ft. to 20 ft.	
					14 Nearest source of possible contamination: Livestock ft. 150' Direction NW Type Pen Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation * Details above Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley Well Location is 225 Ft west of East Section line + 63 Ft north of South Section line			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ronald Heffron Drilling #113 Business name _____ License No. _____ Address Route 3, Winfield, Kans. Signed Ronald Heffron Date 10-15-76 Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

35 SE 1 2 SE SE SE