

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Brown	Fraction SE 1/4 NE 1/4 SE 1/4	Section number 14	Township number T 3	Range number R 16
2. Distance and direction from nearest town or city: 2 1/2 East and 2 miles North of Powhatten				3. Owner of well: Don. O. Loyd R.R. or street: R # 5 City, state, zip code: Hiawatha, Kansas. 66434		
4. Locate with "X" in section below:		Sketch map:				
5. Type and color of material		From	To	6. Bore hole dia. 42 in. Completion date 5-24-83 Well depth 47 ft. Bore hole 50 "		
Brown windblown		0	6	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input checked="" type="checkbox"/> to 11 " <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Red <input type="checkbox"/> Reverse rotary		
Very fine light brown windblown		6	9	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Same - fairly dry and hard		9	17	9. Casing: Material Concrete Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 325 lbs./ft. Dia 36 in. to 47 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 3 "		
Brown windblown with darker brown streaks		17	29	10. Screen: Manufacturer's name _____ Type _____ Dia. _____ Slot/gauze _____ Length _____ Set between _____ ft. and _____ ft. _____ ft. and _____ ft.		
Coarse sand and small gravel - very productive		29	42	11. Static water level: _____ mo./day/yr. 28 ft. below land surface Date 5-24-83		
Soft blue shale - gets harder at 47'		42	47	12. Pumping level below land surfaces: 31 ft. after 1 hrs. pumping 10 g.p.m. 33 ft. after 2 hrs. pumping 10 g.p.m. Estimated maximum yield 8 g.p.m.		
(Use a second sheet if needed)				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 11 ft.		
				16. Nearest source of possible contamination: ft. 300 Direction SW Type lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 1162 Rm	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Popplewell Well Boring 320 Business name _____ licensed by _____ Address R.R. 1 Amity, Mo. 64422 Signed Jerry Popplewell Date 6-4-83 Authorized representative			