

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Brown	Fraction SW 1/4 NW 1/4 NW 1/4	Section number 26	Township number T 3	Range number R 16 E 16																								
2. Distance and direction from nearest town or city: 1 1/2 miles east and 1 3/4 Miles north of Powhattan				3. Owner of well: Dwight Meyer R.R. or street: City, state, zip code: Powhattan, Kansas 66527																										
4. Locate with "X" in section below:				6. Bore hole dia. 36 in. Completion date 1-6-82 Well depth 52 ft. Bore hole 44" to 11 feet																										
<div style="display: flex; align-items: center;"> <div style="border: 1px solid black; padding: 5px; margin-right: 10px;"> <p style="text-align: center;">N</p> <table border="1" style="width: 100%; text-align: center;"> <tr><td>X</td><td>NW</td><td>NE</td></tr> <tr><td></td><td></td><td></td></tr> <tr><td></td><td>SW</td><td>SE</td></tr> </table> <p style="text-align: center;">S</p> <p style="text-align: center;">1 Mile</p> </div> <div style="margin-left: 10px;"> <p>Sketch map:</p> </div> </div>				X	NW	NE					SW	SE	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Red <input type="checkbox"/> Reverse rotary																	
X	NW	NE																												
	SW	SE																												
5. Type and color of material				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																										
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 80%;">Type and color of material</th> <th style="width: 10%;">From</th> <th style="width: 10%;">To</th> </tr> </thead> <tbody> <tr> <td>Black topsoil</td> <td>0</td> <td>1 1/2</td> </tr> <tr> <td>Very hard brown windblown with black streaks in it</td> <td>1 1/2</td> <td>16</td> </tr> <tr> <td>Same - somewhat softer</td> <td>16</td> <td>25</td> </tr> <tr> <td>Soft lite brown shale</td> <td>25</td> <td>44</td> </tr> <tr> <td>Soft shale mixed with gravel and bearing water</td> <td>44</td> <td>48</td> </tr> <tr> <td>Very hard blue gray shale</td> <td>48</td> <td>52</td> </tr> <tr> <td>Limestone bedrock</td> <td>52</td> <td></td> </tr> </tbody> </table>				Type and color of material	From	To	Black topsoil	0	1 1/2	Very hard brown windblown with black streaks in it	1 1/2	16	Same - somewhat softer	16	25	Soft lite brown shale	25	44	Soft shale mixed with gravel and bearing water	44	48	Very hard blue gray shale	48	52	Limestone bedrock	52		9. Casing: Material Concrete (Highly above or below) Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 200 lbs./ft. Dia. 30 in. to 52 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 2"		
Type and color of material	From	To																												
Black topsoil	0	1 1/2																												
Very hard brown windblown with black streaks in it	1 1/2	16																												
Same - somewhat softer	16	25																												
Soft lite brown shale	25	44																												
Soft shale mixed with gravel and bearing water	44	48																												
Very hard blue gray shale	48	52																												
Limestone bedrock	52																													
				10. Screen: Manufacturer's name _____ Type _____ Dia. _____ Slot/gauze _____ Length _____ Set between _____ ft. and _____ ft. _____ ft. and _____ ft. Gravel pack? <input type="checkbox"/> Size range of material _____																										
				11. Static water level: _____ mo./day/yr. 35 ft. below land surface Date 1-5-82																										
				12. Pumping level below land surfaces: 44 ft. after 1/2 hrs. pumping 35 g.p.m. 50 ft. after 1 hrs. pumping 35 g.p.m. Estimated maximum yield 3-4 g.p.m.																										
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____																										
				14. Well head completion: _____ Pitless adapter _____ Inches above grade																										
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 11 ft.																										
				16. Nearest source of possible contamination: ft. 400 Direction west Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																										
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																										
(Use a second sheet if needed)																														
18. Elevation: 1158		19. Remarks: Rw X Dwight C. Meyer		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Poppewell Wellboring 320 Business name _____ Address _____ Signed Don Poppewell Date Jan 3, 1982 Authorized representative _____																										