


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

NWNE SW

1 Location of well:	County <b>Doniphan</b>	Township name <b>Wolf River</b>	Fraction <b>SW 1/4</b>	Section number <b>16</b>	Town number <b>3</b>	Range number <b>19 E</b>
Distance and direction from nearest town or city: <b>1 mi. E, 1/2 mi. N of Leona, KANS.</b>			3 Owner of well: <b>CHAS. F. LIBEL</b> Address: <b>Leona, KANSAS.</b>			
Locate with "X" in section below: 		Sketch map:		4 Well depth: <b>58</b> ft. Date of completion <b>2-10-75</b> Well diameter <b>10</b> in. 5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well 7 Casing: Material <b>PVC</b> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>24</b> in. Diam. <b>5"</b> Weight <b>2.33</b> lbs./ft. <b>2</b> in. to <b>58</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth		
2 Type and color of material		From To				
<b>Brown Clay</b>		<b>0</b>	<b>10</b>	8 Screen: Manufacturer <b>Pump Co</b> Type <b>PVC</b> Dia. <b>5"</b> Slot/size <b>.080</b> Length <b>10</b> Set between <b>27</b> ft. and <b>37</b> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>1/8 to 1/4</b>		
<b>Blue Clay</b>		<b>10</b>	<b>30</b>	9 Static water level: <b>20'</b> ft. below land surface Date <b>2-10-75</b>		
<b>Sand-gravel</b>		<b>30</b>	<b>37</b>	10 Pumping level below land surfaces: <b>Air Test</b> — ft. after — hrs. pumping — g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield <b>5</b> g.p.m.		
<b>Blue Shale</b>		<b>37</b>	<b>58</b>	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —		
				12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <b>24</b> <input checked="" type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>27</b> ft. to <b>29</b> ft.		
				14 Nearest source of possible contamination: ft. <b>400</b> Direction <b>North</b> Type <b>Septic</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name — Model number — HP — Volts — Length of drop pipe — ft. capacity — g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation <b>941</b> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		(use a second sheet if needed)		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Strader Drilling Co. Inc. #182</b> Business name License No. Address <b>Rt 1-Hwy. 75N Holton, KANS.</b> Signed <b>Dale Baker</b> Date <b>2-11-75</b> Authorized representative		