

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County WASHINGTON	Fraction C 1/4 1/4 SW 1/4	Section number 36	Township number T 3 S R 2	Range number 2
2. Distance and direction from nearest town or city: 6 SOUTH			3. Owner of well: CALLVIN WILGERS			
Street address of well location if in city: 1/2 E MEADOWVILLE			R.R. or street: ROUTE 1			
			City, state, zip code: WASHINGTON, KANS			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 22 in. Completion date _____		
				Well depth 230 ft. 6-1-77		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material AC Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30 lbs./ft. Dia 12 in. to 230 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 37		
TOPSOIL		0	2	10. Screen: Manufacturer's name S. JOHNSON CONCRETE		
BROWN CLAY		2	13	Type ASBESTOS Dia. 12 Slot/gauze 1/8 Length 52 Set between 178 ft. and 230 ft.		
SANDY CLAY		13	18	Gravel pack? YES Size range of material 4 X 5		
SAND		18	23	11. Static water level: _____ mo./day/yr. 61 ft. below land surface Date 6-1-77		
SANDROCK		23	34	12. Pumping level below land surfaces: 220 ft. after 1 hrs. pumping 500 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 500 g.p.m.		
HARD ROCK		34	37	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
BROWN CLAY		37	98	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
GRAY CLAY		98	134	15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
SANDROCK		134	160	16. Nearest source of possible contamination: ft. 1500 Direction SW Type LTS Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
RED CLAY		160	174	17. Pump: _____ Not installed Manufacturer's name WESTERN LAND ROLLER Model number 11-100-HC HP 80 Volts _____ Length of drop pipe 215 ft. capacity 500 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
RED CLAY		174	175			
SANDROCK		175	230			
STOP		230				
(Use a second sheet if needed)						
18. Elevation: 83		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				Business name GEO COX & SONS INC 358 Address CLIFTON, KANS 66937 Signed Harold Fox Date 6-1-77 Authorized representative		

3
 2
 36
 CSW
 1/4
 1/4
 1/4