

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Doniphan Fraction SW 1/4 SW 1/4 NE 1/4 Section number 1 Township number T 3 S R 20 Range number 20 EW	
2. Distance and direction from nearest town or city: 1 1/2 W 2 N Street address of well location if in city: Troy 3. Owner of well: Ted Smith R.R. or street: RR #1 City, state, zip code: Troy, Ks. 66087	
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>Sketch map:</p> </div> <div> <p>6. Bore hole dia. 12 in. Completion date 5-15-79 Well depth 60 ft.</p> <p>7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material Drc Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC Blue Weight 2.74 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 25Y</p> </div> </div>	
5. Type and color of material	
	From To
Silty Flux Sand	0 18
Gray Silty Clay	18 36
Gray Fine Sand	36 37
Gray Slate & Limestone	37 60
10. Screen: Manufacturer's name Pumped MPI Type PVC Dia. 5" Slot gauge .020 Length 10' Set between 12 ft. and 22 ft. 30 ft. and 40 ft. Gravel pack? yes Size range of material 030/060	
11. Static water level: 10 ft. below land surface Date 5-15-79 mo./day/yr.	
12. Pumping level below land surfaces: RTI Test ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 3 g.p.m.	
13. Water sample submitted: ____ Yes <input checked="" type="checkbox"/> No Date ____ mo./day/yr.	
14. Well head completion: Top Cap ____ Pitless adapter 24 Inches above grade	
15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement ____ Bentonite ____ Concrete Depth: From 0 ft. to 10 ft.	
16. Nearest source of possible contamination: 400 ft. Direction NW Type Lateral Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: 1032 Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: owner to install slab
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER DELG CO INC 182 Business name License No. Address RT 1 Holton, Ks Signed Dale Cabern Date 5-15-79 Authorized representative	

T
R
E
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR = 995 B = 1022