

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County DONIPHAN	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 3	Township number T 3 S R 20 E W	Range number 20
2. Distance and direction from nearest town or city: 3/4 of a mile south of Fanning, Kansas.			3. Owner of well: Roy Moore R.R. or street: R. R. 1 City, state, zip code: Troy, Kansas 66087		
4. Locate with "X" in section below:			6. Bore hole dia. 34 in. Completion date 2/21/77 Well depth 43 Bore hole is 42 " to 1		
<p style="text-align: center;">Sketch map:</p>			<p>7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material concrete Height: <input checked="" type="checkbox"/> Above or below Threading <input type="checkbox"/> Welded <input type="checkbox"/> Surface 30 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 200 lbs./ft. Dia. 30 in. to 43 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 2 IN</p>		
5. Type and color of material			From	To	10. Screen: Manufacturer's name _____
Hard - dry windblown w/brown streaks			0	12	Type _____ Dia. _____
Same - But some softer			12	17	Slot/gauze _____ Length _____
Very light windblown w/brown & black streaks			17	31	Set between _____ ft. and _____ ft. _____ ft. and _____ ft.
Sandy windblown - very soft			31	34	Gravel pack? <input type="checkbox"/> Size range of material _____
Large sand and gravel w/boulders as large as plates, very, very, productive			34	43	11. Static water level: _____ mo./day/yr. 26 ft. below land surface Date 2/18/77
Hard, blue, shale			43		12. Pumping level below land surfaces: 31 ft. after 2 hrs. pumping 30 g.p.m. 31 ft. after 4 hrs. pumping 30 g.p.m. Estimated maximum yield 20 g.p.m.
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
					14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 11 ft.
					16. Nearest source of possible contamination: ft. 300 Direction SW Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. POPPLEWELL WELL BORING 320 Business name _____ License No. _____ Address Amity, MO 64422 Signed Roy Popplewell Date 2/10/77 Authorized representative
18. Elevation: 710	19. Remarks: Concrete slab and vent will be installed by customer. He knows and understands this is a regulation. SIGN HERE Roy Moore				

T 3 S R 20 E W
 Sec 3 NE NE NE