

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

SE-SW-NW

1. Location of well: County Donphan		Traction NE-NE 1/4-NE 1/4		Section number 27		Township number T 3 S R 20		Range number 20 (E/W)	
2. Distance and direction from nearest town or city: 1 E 1.5 N				3. Owner of well: Kenny & Christopher					
Street address of well location if in city: OF Bendena				R.R. or street: RR					
				City, state, zip code: Bendena, KS 66008					
Locate with "X" in section below:		Sketch map:				6. Bore hole dia. 12 in. Completion date 8-10-79 Well depth 118 ft.			
						7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
						9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 29 in. RMP <input type="checkbox"/> PVC 92 Weight 3182 lbs./ft. Dia. 5 in. to 118 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 125B			
5. Type and color of material				From		To		10. Screen: Manufacturer's name Pumpco	
TOP SOIL				0		3		Type PVC Dia. 5	
Clay brown				3		79		Slot/gauge 1.020 Length 10	
Fine sand, WATER bearing				74		76		Set between 70 ft. and 80 ft.	
Lime & Terr, grey				76		92		Gravel pack? <input checked="" type="checkbox"/> Size range of material 030x1060	
shale, grey				92		118		11. Static water level: 72 ft. below land surface Date 8-10-79	
				11				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 5 g.p.m.	
								13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
								14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 23 inches above grade	
								15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
								16. Nearest source of possible contamination: ft. 100 Direction S Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
								17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)									
18. Elevation: 1085		19. Remarks: owner TO INSTALL SLAB				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER DRUG CO 182 Business name License No. Address Holtan KS Signed Dale Asken Date 8-10-79 Authorized representative			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley									

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR=1009 V=1013