USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Washington	NE 1/4 SE 1/4 NE 1/4	9	T 3 S	R 3 E E/W

2. Distance and direction from nearest town or city: 1 W - ¼ S of Washington
Street address of well location if in city:

3. Owner of well: Donald Tegethof
R.R. or street:
City, state, zip code: Washington, Kansas 66968

4. Locate with "X" in section below: Sketch map:

N
NW NE X
W E
SW SE
S
1 Mile 1 Mile

6. Bore hole dia. 8 in. Completion date
Well depth 61 ft. 7/26/'79

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material PVC Height: Above ~~or below~~
Threaded ___ Welded ___ Surface 12 in.
RMP ___ PVC X Weight 3 lbs./ft.
Dia. 5 in. to 61 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth ~~gauge~~ .258

5. Type and color of material	From	To
Top soil & clay	0	12
Sandrock	12	16
Clay	16	48
Sandrock	48	60
Clay	60	61

(Use a second sheet if needed)

10. Screen: Manufacturer's name Pumpco Supply
Type PVC Dia. 5
Slot/gauze 1/16 Length 20
Set between 41 ft. and 61 ft.
___ ft. and ___ ft.
Gravel pack? X Size range of material 1/8-¼

11. Static water level: 45 ft. below land surface Date 7/26/'79 mo./day/yr.

12. Pumping level below land surfaces: 58 ft. after 1 hrs. pumping 20 g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 24 g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes X No Date

14. Well head completion:
__ Pitless adapter 12 Inches above grade

15. Well grouted? X
With: X Neat cement __ Bentonite __ Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: NONE
ft. ___ Direction ___ Type ___
Well disinfected upon completion? X Yes __ No

17. Pump: X Not installed
Manufacturer's name
Model number ___ HP ___ Volts ___
Length of drop pipe ___ ft. capacity ___ g.p.m.
Type:
__ Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

18. Elevation: 1329'
Topography:
X Hill
__ Slope
__ Upland
__ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Business name Cox - Beswick License No. 361
Address Clifton, Kansas 66937
Signed Francis Cox Date 7/31/79
Authorized representative

T 3 S R 3 E (E/W) Sec 9 1/4 NE 1/4 SE 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

M1-1023