


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Washington	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 15	Township number T 3 S R 3 E	Range number E/W																		
2. Distance and direction from nearest town or city: 1 1/4 W - 1 S - 1/2 W of Washington			3. Owner of well: Stigge & Sons, Inc. R.R. or street: Route # 1 City, state, zip code: Washington, Kansas 66968																				
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 8 in. Completion date 7-24-79 Well depth 123 ft.																				
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																				
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Low <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																				
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:80%;">Type and color of material</th> <th style="width:10%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr> <td style="text-align:center;">Clay</td> <td style="text-align:center;">0</td> <td style="text-align:center;">12</td> </tr> <tr> <td style="text-align:center;">Sandrock</td> <td style="text-align:center;">12</td> <td style="text-align:center;">15</td> </tr> <tr> <td style="text-align:center;">Clay</td> <td style="text-align:center;">15</td> <td style="text-align:center;">85</td> </tr> <tr> <td style="text-align:center;">Sandrock</td> <td style="text-align:center;">85</td> <td style="text-align:center;">120</td> </tr> <tr> <td style="text-align:center;">Clay</td> <td style="text-align:center;">120</td> <td style="text-align:center;">123</td> </tr> </tbody> </table>			Type and color of material	From	To	Clay	0	12	Sandrock	12	15	Clay	15	85	Sandrock	85	120	Clay	120	123	9. Casing: Material PVC Height: above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 123 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth 3/8 No. 258		
			Type and color of material	From	To																		
Clay	0	12																					
Sandrock	12	15																					
Clay	15	85																					
Sandrock	85	120																					
Clay	120	123																					
			10. Screen: Manufacturer's name Pumpco Supply, Inc. Type PVC Dia. 5 Slot/gauze 1/16 Length 20 Set between 103 ft. and 123 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-1/4																				
			11. Static water level: 76 ft. below land surface Date 7/24/79 mo./day/yr.																				
			12. Pumping level below land surfaces: 110 ft. after 1 hrs. pumping 40 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 50 g.p.m.																				
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.																				
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade																				
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.																				
			16. Nearest source of possible contamination: Cattle lot ft. 200 Direction SE Type Downhill Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																				
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																				
18. Elevation: 1350			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Cox - Beswick 361 Business name License No. Address Clifton, Kansas 66937 Signed Francis Cox Date 7/25/79 Authorized representative																				
19. Remarks:																							
18. Elevation: 1350 Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley																							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5