

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215


Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

NW NE  
SW SE

1. Location of well: County Washington Fraction SW 1/4 Section number 4 Township number 3 Range number 5 E/W

2. Distance and direction from nearest town or city: Service Station So. Hanover Pony Express Street address of well location if in city: 2 M. So + 1/2 West

3. Owner of well: Kenneth Craig R.R. or street: Hanover Kans City, state, zip code: Hanover Kans

4. Locate with "X" in section below: Sketch map: 

6. Bore hole dia. 10 in. Completion date 7-9-76  
Well depth 90 ft.

7.  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

8. Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Stock  
 Lawn  Oil field water  Other

9. Casing: Material PVC Height: Above or below  
Threaded  Welded  Surface 15 in.  
RMP  PVC  Weight 200 lbs./ft.  
Dia. 5 in. to 92 ft. depth Wall Thickness: inches or  
Dia. 5 in. to 92 ft. depth gage No. 200

5. Type and color of material	From	To
<u>top soil</u>	<u>0</u>	<u>1</u>
<u>clay red</u>	<u>1</u>	<u>21</u>
<u>Rock yellow limestone</u>	<u>21</u>	<u>48</u>
<u>Shale Blue</u>	<u>48</u>	<u>51</u>
<u>Rock yellow limestone</u>	<u>51</u>	<u>56</u>
<u>Shale Blue</u>	<u>56</u>	<u>60</u>
<u>Clay Red</u>	<u>60</u>	<u>92</u>

10. Screen: Manufacturer's name MPI Pumpco  
Type PVC Dia. 5  
Slot/gauze 0.50 Length 40  
Set between 40 ft. and 80 ft.  
Gravel pack?  Size range of material 1/4-1/2

11. Static water level: 36 ft. below land surface Date 7-9-76 mo./day/yr.

12. Pumping level below land surfaces:  
     ft. after      hrs. pumping      g.p.m.  
     ft. after      hrs. pumping      g.p.m.  
Estimated maximum yield 36 g.p.m.

13. Water sample submitted:      mo./day/yr.  
Yes  No  Date 7-9-76

14. Well head completion:  
 Pitless adapter      inches above grade

15. Well grouted?  1-2  
With:  Neat cement  Bentonite  Concrete  
Depth: From 15 ft. to 4 ft.

16. Nearest source of possible contamination: 100 ft. Direction SW Type Ditch  
Well disinfected upon completion?  Yes  No

17. Pump:  Not installed  
Manufacturer's name       
Model number      HP      Volts       
Length of drop pipe      ft. capacity      g.p.m.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

(Use a second sheet if needed)

18. Elevation: 1320  
Topography:  Hill  Slope  Upland  Valley

19. Remarks:

20. Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Strader Drilling Co 23  
Business name Blue Rapids License No.       
Address       
Signed Harold Strader Date 7-9  
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5