


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County WASHINGTON	Township name LITTLE BLUE	Fraction NE 1/4 NW 1/4	Section number 23	Town number T-3-S	Range number R-5-E
Distance and direction from nearest town or city:	5 1/2 mi N-E of Hanover		3 Owner of well: BOB HARLAN			
Street address of well location if in city:			Address: Barnes RR Hanover, Kans			
Locate with "X" in section below:	Sketch map:		4 Well depth: 102 ft. Date of completion 11 SEPT 1975 Well diameter 7 in.			
			5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>			
			7 Casing: Material RMP Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. _____ Weight _____ lbs./ft. _____ 5 in. to 102 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth			
2	Type and color of material	From	To	8 Screen: Manufacturer Jess & Lowell Type RMP Dia. 5" Slot/gauze 0.610 Length 20' Set between 102 ft. and 82 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 78		
	Top Soil	0	7	9 Static water level: 88 ft. below land surface Date 11 SEPT 75		
	YELLOW CLAY	7	14	10 Pumping level below land surfaces: Balance test _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 25 g.p.m.		
	YELLOW ROCK	14	16	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
	YELLOW CLAY	16	65	12 Well head completion: N/A <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
	RED CLAY	65	88	13 Well grouted? <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 10 ft. to 21 ft.		
	YELLOW POROUS Limestone	88	102	14 Nearest source of possible contamination: N/A ft. 300 Direction east Type Farm Bldg Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed).						
16 Remarks: elevation 1365	elevation many places in drilling a well we run into bedrock from 10 to 25 ft + if so we ream the hole out large into top of this rock then our grout runs into this bedrock this seals out any water that may soak into the ground + get under the grout + get into the well			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Drilling Co. 137 Business name _____ License No. _____ Address Blue Rapids, KS Signed Harold Strader Date 9-11-75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5