

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County <b>Marshall</b>	Fraction <b>NE 1/4 - SE 1/4 SE 1/4</b>	Section number <b>23</b>	Township number <b>T 3 S R 6 E</b>	Range number <b>EW</b>	
2. Distance and direction from nearest town or city: Street address of well location if in city:	<b>5 N + 2 E of Waterville</b>		3. Owner of well: <b>Marshall Driffee</b> R.R. or street: City, state, zip code: <b>Waterville, Kans. 66548</b>			
4. Locate with "X" in section below: N W E S 1 Mile	Sketch map: 		6. Bore hole dia. <b>8 1/2</b> in. Completion date Well depth <b>83</b> ft. <b>5-17-77 mnc</b>			
5. Type and color of material	From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
	<b>Top soil</b>	<b>0</b>	<b>2</b>	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
	<b>Clay Brown</b>	<b>2</b>	<b>30</b>	9. Casing: Material <b>PLS</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>78 mnc</b> RMP <input checked="" type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <b>18</b> lbs./ft. Dia. <b>5</b> in. to <b>83</b> ft. depth Wall Thickness: inches or Dia. <b>5</b> in. to <b>83</b> ft. depth Gage No. <b>200</b>		
	<b>Clay Tan</b>	<b>30</b>	<b>37</b>	10. Screen: Manufacturer's name _____ Type <b>PVC</b> Dia. <b>5</b> Slot/gauze <b>.030</b> Length <b>20</b> Set between <b>57</b> ft. and <b>77</b> ft. _____ ft. and _____ ft. Gravel pack? <b>YES</b> Size range of material <b>Red</b>		
	<b>Rock Limestone</b>	<b>37</b>	<b>38</b>	11. Static water level: <b>mnc</b> mo./day/yr. <b>58</b> ft. below land surface Date <b>5-17-77</b>		
	<b>Clay Tan</b>	<b>38</b>	<b>50</b>	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>25</b> g.p.m.		
	<b>Clay Brown</b>	<b>50</b>	<b>57</b>	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____		
	<b>Rock Limestone</b>	<b>57</b>	<b>68</b>	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
	<b>shale Blue</b>	<b>68</b>	<b>83</b>	15. Well grouted? <b>YES</b> With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft. <b>mnc</b>		
	(Use a second sheet if needed)			16. Nearest source of possible contamination: ft. _____ Direction _____ Type <b>None</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <b>mnc</b> No		
			17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation: <b>1095</b>	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Blue Valley Drilling 234</b> Business name _____ License No. _____ Address <b>Blue Rapids, Kans</b> Signed <b>Paul Smith</b> Date <b>5-17-77</b> Authorized representative _____ <b>mnc</b>			

T 3 S R 6 E  
W 1/4 NE SE SE  
1/4 1/4 1/4