

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

South West

3

1. Location of well: County *Marshall* Fraction *South West NW 1/4 SW 1/4 SW 1/4* Section number *33* Township number *T 2 South* Range number *Range 7 east*

2. Distance and direction from nearest town or city: *South of Marysville 3/4 West* 3. Owner of well: *Don Kraemer*
Street address of well location if in city: *Marysville Kans*
City, state, zip code: *Marysville Kans*

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. *10* in. Completion date *May 3-77*
Well depth *95* ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material *PVC* Height: Above or below
Threaded Welded Surface *14* in.
RMP PVC Weight *95* lbs./ft.
Dia. *3* in. to *95* ft. depth Wall Thickness: inches or
Dia. in. to ft. depth gage No. *Sch 40*

10. Screen: Manufacturer's name *Pumpco*
Type *PVC* Dia. *40*
Slot/gauze *040* Length *40*
Set between *56* ft. and *95* ft.
ft. and ft.
Gravel pack? Size range of material *1/4"*

11. Static water level: *40* ft. below land surface Date *5-3-77*

12. Pumping level below land surfaces:
 ft. after hrs. pumping g.p.m.
 ft. after hrs. pumping g.p.m.
Estimated maximum yield *4.5* g.p.m.

13. Water sample submitted: Yes No Date

14. Well head completion: Pitless adapter Inches above grade

15. Well grouted?
With: Neat cement Bentonite Concrete
Depth: From *20* ft. to *8* ft.

16. Nearest source of possible contamination: *150* ft. Direction *South* Type *Creek*
Well disinfected upon completion? Yes No

17. Pump: Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

5. Type and color of material	From	To
<i>Clay</i>	<i>0</i>	<i>10</i>
<i>Rock yellow Limestone</i>	<i>10</i>	<i>21</i>
<i>Shale Brown</i>	<i>21</i>	<i>30</i>
<i>))</i>	<i>30</i>	<i>39</i>
<i>Rock Hard Flinty</i>	<i>39</i>	<i>43</i>
<i>Rock Lime & Flint</i>	<i>43</i>	<i>44</i>
<i>Rock Limestone & Flint</i>	<i>44</i>	<i>50</i>
<i>)) Flint</i>	<i>50</i>	<i>58</i>
<i>Rock Flint</i>	<i>58</i>	<i>70</i>
<i>Rock Blue Limestone</i>	<i>70</i>	<i>73</i>
<i>Shale Blue</i>	<i>73</i>	<i>93</i>

(Use a second sheet if needed)

18. Elevation: *140*
Topography: Hill Slope Upland Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Strader Drelling *237*
Business name *Blue Rapids* License No. *1/4*
Address *Barold Strader*
Signed *Barold Strader* Date *5-5-77*
Authorized representative