

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1245

1. Location of well: County Marshall Tracton ~~NE 1/4~~ NW 1/4 NW 1/4 NE 1/4 Section number 1 Township number T 3 S Range number R 8 E

2. Distance and direction from nearest town or city: Home City 2 east 3. Owner of well: R.F.P. Darrel Raebel
Street address of well location if in city: South 3/4 east so side R.R. or street:
City, state, zip code: Home City Kans

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 5 in. Completion date 9-23-76
Well depth 83 ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material PVC Height Above or below
Threaded Welded Surface 18 in.
RMP PVC Weight 258 lbs./ft.
Dia. 5 in. to 83 ft. depth Wall thickness: 3/8 inches or
Dia. 5 in. to 83 ft. depth gage No. Sch 40

10. Screen: Manufacturer's name Pumped
Type PVC Dia. 5
Slot/gauge .040 Length 40
Set between 43 ft. and 83 ft.
Gravel pack? Size range of material 1/8 X 1/4

11. Static water level: 35 ft. below land surface Date 9-23-76 mo./day/yr.

12. Pumping level below land surfaces:
____ ft. after ____ hrs. pumping ____ g.p.m.
____ ft. after ____ hrs. pumping ____ g.p.m.
Estimated maximum yield 30 g.p.m.

13. Water sample submitted: ____ mo./day/yr.
Yes No Date

14. Well head completion: NA
____ Pitless adapter ____ Inches above grade

15. Well grouted?
With: ____ Neat cement ____ Bentonite Concrete
Depth: From 15 ft. to 4 ft.

16. Nearest source of possible contamination:
ft. 900 Direction west Type feed lot
Well disinfected upon completion? Yes No

17. Pump: Not installed
Manufacturer's name ____ HP ____ Volts ____
Model number ____ Length of drop pipe ____ ft. capacity ____ g.p.m.
Type:
____ Submersible ____ Turbine
____ Jet ____ Reciprocating
____ Centrifugal ____ Other

18. Elevation: Topography: Hill Slope Upland Valley

19. Remarks: (Use a second sheet if needed)

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Strader Drilling Co. License No. 1/5
Business name Blue Rapids
Address Harold Strader Date 9-23-76
Signed Harold Strader Authorized representative

T
R
W
E
Sec
1
1/4
1/4
1/4