
## WATER WELL RECORD KSA 82a-1201-1215



Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

)	County	Fraction	Section number		Township number	Range number		7	
1. Location of well:	Marshall	NE 1/4 NE 1/4 N	<b>W</b> 1/4	3	2	т 3 ѕ	R 9	E/ <b>3X</b>	Č
Frankfort; 3/4 Mi. W. Street address of well location if in city:					street: Marshall County RWD #3 tate, zip code: Frankfort, Kansas				
4. Locate with "X" in section below:  Sketch map:						6. Bore hole dia. 30 in Well depth 93½ ft.	Completion da	 /80	-
						7Cable toolRotaryHollow rodJetted 8. Use:DomesticX PriIrrigationA	Driven BoredX ublic supply	Dug Reverse rotar Industry	<u>y</u>
S  1 ———————————————————————————————————									
5. Type and color of material					То	Dia in. to ft. depth gage No. • 330"  10. Screen: Manufacturer's name Johnson			
Fill dirt					3	Wire Wrap (Stainless)  Type Wire Wrap Dia. 16"			
Soil					6	Slot/gauze #40 Set between 852		.0' 95½ ft	-
Clay				6	35	Gravel pack? Yes Size ra	and inge of material_		<u>'</u>
Med. to coarse sand & gravel w/boulders				35	42	11. Static water level:5ft. below land sui	rface Date <u>5/</u>	'mo./day/yr '24/79	-
Fine sand				42	85	12. Pumping level below land	d surfaces:	266	
Med. to coarse sand & gravel w/boulders				85	93	67 ft. after 5 hrs. pumping 266 g.p.m. ft. after hrs. pumping g.p.m.			
Blue shale				93		13. Water sample submitted: Yes X No	Date	mo./day/yr	
						14. Well head completion:  X Pitless adapter	36 Inches al	bove grade	-
						15. Well grouted? Yes With: Neat cement Depth: From _7 ft. to	Bentonite	X Concrete	, ]
						16. Nearest source of possible ft. 1500 Direction 16. Well disinfected upon complete	e_contamination:  W Type . etion? X Ye		_
						17. Pump:  Manufacturer's name Lay  Model number 6RKHC	ne & Bo	owler Volts 46	
		-				Length of drop pipe 84  Type: X Submersible	ft. capacity ${\hat 4}$	260 <sub>g.p.m</sub> . urbine	•
(Use a second sheet if needed)						Jet Centrifugal	Re	eciprocating ther	Sec
18. Elevation: 19. Remarks:						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Topography: Hill Slope						Layne Wester  Business name Address Wichita	n Co.	102 License No	1/4 1/4
Upland X Valley						Signed Authorized rec	nivido	Date 1/34/8	<b>2</b>