

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

SW SW NW

BCC

| | | | | | |
|---|--|---|--|---------------------------------|--|
| 1. Location of well: | County BROWN | Fraction NE 1/4 NE 1/4 NW 1/4 | Section number 9 | Township number T 4 S | Range number R 18 E/W |
| 2. Distance and direction from nearest town or city: Street address of well location if in city: | 1/2 E - 3 N. EVEREST, KANSAS | | 3. Owner of well: JOE KATZ R.R. or street: City, state, zip code: EVEREST, KS. | | |
| 4. Locate with "X" in section below: Sketch map: | <p>house X well BARN SEPTIC TANK DRAINAGE IATERS</p> | | 6. Bore hole dia. 10 in. Completion date 11-24-75 Well depth 150 ft. | | |
| 5. Type and color of material | From | | To | | 7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary |
| TOP SOIL | 0 | | 6 | | 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other |
| Shale (yellow) | 6 | | 33 | | 9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP PVC QL Weight 2.33 lbs./ft. Dia. 5 in. to 150 ft. depth Wall Thickness: inches or Dia. 5 in. to 150 ft. depth gage No. 1214 |
| Limestone (Brown) | 33 | | 53 | | 10. Screen: Manufacturer's name Pumco Type PVC Dia. 5" Slot/gauge 80 Length 20' Set between 95 ft. and 115 ft. ft. and 115 ft. Gravel pack? yes Size range of material 4x6 |
| L. Shale (blue) | 53 | | 71 | | 11. Static water level: 100 ft. below land surface Date 11-29-75 mo./day/yr. |
| Limestone (Brown) | 71 | | 80 | | 12. Pumping level below land surfaces: AIR TEST ft. after 0 hrs. pumping 0 g.p.m. ft. after 0 hrs. pumping 0 g.p.m. Estimated maximum yield 40 gph g.p.m. |
| Shale (grey) | 80 | | 100 | | 13. Water sample submitted: yes No X Date 11-29-75 mo./day/yr. |
| Sandstone (grey) | 100 | | 105 | | 14. Well head completion: NOT INSTALLED Pitless adapter CAPPED inches above grade |
| Shale (grey) | 105 | | 129 | | 15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. |
| Limestone (grey) | 129 | | 134 | | 16. Nearest source of possible contamination: 100 ft. NE Type SEPTIC TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Shale (blue) | 134 | | 150 | | 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |
| (Use a second sheet if needed) | | | | | |
| 18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley | 19. Remarks: Joseph A. Katz will install slab | | | | |
| 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Stroder Drilling Co Inc 182 Business name License No. Address RT 1 Holton Kansas Signed Dale Ashen Date 11-29-75 Authorized representative | | | | | |

BR = 1084

7 - 910

4 180 9 NE NE NW
1/4 1/4 1/4