

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County WASHINGTON Fraction C 1/4 SE 1/4 SE 1/4 Section number 23 Township number T 4 S R 2 Range number 2 EW	
2. Distance and direction from nearest town or city: 4 WEST Street address of well location if in city: OF LINN	
3. Owner of well: HARVEY HERRS R.R. or street: RR # 2 City, state, zip code: LINN, KANS 66953	
4. Locate with "X" in section below: Sketch map: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>1 Mile</p> <p>1 Mile</p> </div> </div>	
6. Bore hole dia. 8 in. Completion date: 7/7/76 Well depth 139 ft.	
7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material PVC Height: Above or below 2 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 5 lbs./ft. Dia. 5 in. to 139 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 1214	
5. Type and color of material	
	From To
TOPSOIL	0 2
RED CLAY	2 18
BROWN SANDY CLAY	18 22
GRAY CLAY	22 30
SANDROCK	30 33
GRAY CLAY	33 55
SANDROCK	55 62
GRAY CLAY	62 66
GRAY CLAY w/ROCK LAYERS	66 112
SANDROCK	112 140
STOP	140
10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" Slot gauze 1/4 Length 30' Set between 119 ft. and 139 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/8 x 1/4	
11. Static water level: <input type="checkbox"/> No./day/yr. 70 ft. below land surface Date 7/7/76	
12. Pumping level below land surface <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 25 g.p.m.	
13. Water sample submitted: <input type="checkbox"/> No./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
16. Nearest source of possible contamination: HOG ft. 125 Direction WEST Type PUMPCO Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: 1450 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. GEO COX & SONS INC 258 Business name License No. Address ELLIOTTON KANSAS Signed Daugherty Date 7/7/76 Authorized representative	

T 4 R 2 S W 23 Sec 23 CSE SE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5