

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County WASHINGTON	Fraction NE 1/4 NW 1/4 NW 1/4	Section number 35	Township number T 4 S R	Range number 2 EW
2. Distance and direction from nearest town or city: 2 1/2 N - 2 W			3. Owner of well: DELBERT MEYERS			
Street address of well location if in city: PALMER			R.R. or street: City, state, zip code: LINN, KANS 66493			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date _____ Well depth 140 ft. 12-26-78		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 140 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1258		
				10. Screen: Manufacturer's name _____ PUMPCO Type PVC Dia. 5" Slot/gauze 1/16 Length 20' Set between 120 ft. and 140 ft. _____ ft. and _____ ft. Gravel pack? YES Size range of material 4x4		
				11. Static water level: _____ mo./day/yr. 60 ft. below land surface Date 12-26-78		
				12. Pumping level below land surfaces: _____ ft. after NA pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 _____ g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 120 Direction WEST Type LOTS Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation: 400		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Wayne Leo Sono Inc 359 Business name License No. Address Raytown, Kans 66493 Signed Wayne Leo Date 1-16-79 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T-4-20-35 NE NW NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5