

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Washington	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 1	Township number T 4 S R 3 E E2W	Range number
2. Distance and direction from nearest town or city:	6 South of Washington		3. Owner of well: Ralph Holsch		
Street address of well location if in city:			R.R. XXXX # 1		
			City, state, zip code: Washington, Kansas 66968		
4. Locate with "X" in section below:			Sketch map:		
			6. Bore hole dia. 8 in. Completion date _____ Well depth 63 ft. 7-5-79		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PVC Height: Above or below _____ Threaded _____ Welded _____ Surface 1 1/2" in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 63 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. .258		
5. Type and color of material			From	To	10. Screen: Manufacturer's name _____ Pumpeco Supply
top soil & clay			0	30	Type PVC Dia. 5
sandrock			30	65	Slot/gauze 1/16" Length 20'
clay			65	70	Set between 43 ft. and 63 ft. _____ ft. and _____ ft.
sandrock			70	73	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 - 1/4
clay			73	75	11. Static water level: _____ mo./day/yr. 25 ft. below land surface Date 7/2/79
sandrock			75	95	12. Pumping level below land surfaces: 55 ft. after 1 hrs. pumping 50 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 60 g.p.m.
shale			95	105	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: None ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
			(Use a second sheet if needed)		
18. Elevation: 1420'	19. Remarks: <i>This report was held up to see if we installed the pump. We aren't going to install it. 9-8-79</i>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Cox - Beswick 361 Business name Clifton, Kansas License No. 66937 Address 7/7/79 Signed Manis Cox Date 7/7/79 Authorized representative		

T-4
 R-3
 W-E
 Sec-1
 1/4 1/4 1/4 1/4
 SW SW SW SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5