USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	WASHINGTON	SE 1/4 NW 1/4 SE 1/4	35	T 5 S	R 1 E/W

2. Distance and direction from nearest town or city:
Street address of well location if in city: IN CLIFTON

3. Owner of well: ROY TOLL
R.R. or street: ROUTE 1
City, state, zip code: CLIFTON, KANS 66937

4. Locate with "X" in section below: Sketch map:

N — NW — NE — W — E — SW — SE (X) — S — 1 Mile — 1 Mile

6. Bore hole dia. 8 in. Completion date
Well depth 99 ft. 3-30-78

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material PVC Height: (Above) or below
Threaded ___ Welded X Surface 12 in.
RMP ___ PVC X Weight 3 lbs./ft.
Dia. 5 in. to 99 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. 1258

5. Type and color of material	From	To
TOPSOIL	0	3
BROWN CLAY	3	34
SANDROCK	34	35
BROWN CLAY	35	46
SANDROCK	46	98
BLUE SHALE	98	100
STOP	100	

(Use a second sheet if needed)

10. Screen: Manufacturer's name PUMPCO
Type PVC Dia. 5"
(Slot)/gauze 1/16 Length 20'
Set between 79 ft. and 99 ft.
___ ft. and ___ ft.
Gravel pack? YES Size range of material 1/8 X 1/4

11. Static water level: mo./day/yr.
55 ft. below land surface Date 3-30-78

12. Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after NA hrs. pumping ___ g.p.m.
Estimated maximum yield 20+ g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes X No Date

14. Well head completion:
__ Pitless adapter 12 Inches above grade

15. Well grouted? YES
With: X Neat cement __ Bentonite __ Concrete
Depth: From 0 ft. to 20 ft.

16. Nearest source of possible contamination: SOLID
ft. 100 Direction WEST Type SEWER
Well disinfected upon completion? X Yes __ No

17. Pump: X Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.p.m.
Type:
__ Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

18. Elevation: 1330'
Topography:
__ Hill
__ Slope
✓ Upland
__ Valley

19. Remarks:
THIS WELL TO BE INSIDE BASEMENT AFTER CONSTRUCTION

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Business name DARYL COX + SONS INC License No. 359
Address CLIFTON KANS 66937
Signed Daryl Cox Date
Authorized representative 3-30-78

T 5 R 1 E/W Sec 35 1/4 SE 1/4 NW 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023