


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

S 10 E 16 SE SE SE
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Marshall	Township name Cleveland	Fraction S.E. 1/4	Section number 16	Town number 5	Range number 10 E
Distance and direction from nearest town or city: Lillis, Ks.			3 Owner of well: Edna Cogswell			
Street address of well location if in city: LOTS-17-18-Block 12			Address: Frankfort Kans			
Locate with "X" in section below: N  W E S 1 Mile		Sketch map:		4 Well depth: 56 ft. Date of completion 10-9-75 Well diameter 5 in.		
2 Type and color of material				5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Type and color of material				7 Casing: Material PLST. Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 2' in. Diam. 5" Weight 200 lbs./ft. 56 5 in. to 56 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth		
				8 Screen: Manufacturer Pampro Type PVC Dia. 5" Slot/gauze 100 Length 30' Set between 26 ft. and 56 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material —		
Type and color of material				9 Static water level: 26 ft. below land surface Date 10-9-75		
				10 Pumping level below land surfaces: 30 ft. after 2 hrs. pumping 10 g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield 10 g.p.m.		
Type and color of material				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —		
				12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
Type and color of material				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 4 ft. to 14 ft.		
				14 Nearest source of possible contamination: CEPTIC ft. 120 Direction South Type TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Type and color of material				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name SEARS Model number — HP 1/2 Volts 115 Length of drop pipe 40 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		
Type and color of material				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harpers Drilling Service 176 Business name Blue Rapids 176 License No. Address Blue Rapids 176 Signed C. E. Harpers Date 10-9-75 Authorized representative		

5 10 E 16 SE SE SE