

18

W/D

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

baa

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

NENE-NW 13

1. Location of well: County NEMAH		Fraction NW 1/4 NW 1/4 NE 1/4	Section number 13	Township number T 5 S	Range number R 13 EW
2. Distance and direction from nearest town or city: 1 N - 1/2 W Street address of well location if in city: Bancroft			3. Owner of well: Leland Porter R.R. or street: RR City, state, zip code: Wetmore, Ks. 66550		
4. Locate with "X" in section below: Lots across Road Sketch map: 			6. Bore hole dia. 10 in. Completion date 4-7-77 Well depth 71 ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC Cement Weight 2.74 lbs./ft. Dia. 5 in. to 21 ft. depth Wall Thickness: inches or Dig. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 258		
			<input checked="" type="checkbox"/> Screen: Manufacturer's name Pumped		
			Type PVC Dia. 5 Slot/gauze 030 Length 10' Set between 23 ft. and 33 ft. 38 ft. and 48 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 030-060		
			11. Static water level: mo./day/yr. 20 ft. below land surface Date 4-7-77		
			12. Pumping level below land surfaces: air test ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 25 g.p.m.		
			13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
			14. Well head completion: Top Coped <input type="checkbox"/> Pitless adapter 24 inches above grade		
			15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.		
			16. Nearest source of possible contamination: Feed ft. 500 Direction North Type Lots Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 1270 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley			19. Remarks: Owner will pour cement slab around well		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRAKER DRUG CO June 18 1977 Business name _____ License No. _____ Address RT 1 Holton, Ks Signed Dale Peterson Date 4-9-77 Authorized representative		

5-130W-12
R
Sec
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR < 1199 E = 1250