

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

NW NW NW bbb

1. Location of well: County Jackson Fraction NE 1/4 ~~NW 1/4~~ NW 1/4 Section number 11 Township number T 5 Range number S 15 E

2. Distance and direction from nearest town or city: 3 mi. N. Street address of well location if in city: Netawaka

3. Owner of well: Bill Hanglicek R.R. Netawaka, Kan. 66516

4. Locate with "X" in section below:

5. Type and color of material

	From	To
Tap Soil	0	4
Brown Clay	4	8
Brown Sandy Clay	8	27
Brown Silty Clay	27	38
Brown Sandy Clay	38	43
Gray Clay	43	87
Gray med. Cor. Gravel	87	91
Gray Clay	91	94
Gray Sandy Clay	94	96
Gray 1/2 x 3/4 Gravel &	96	102
1x1 Br. Flint Gravel		
Red Shale	102	103
Gray Shale	103	

6. Bore hole dia. 10 in. Completion date 1-26-77
Well depth 103 ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material PVC Height: Above or below
Threaded Welded Surface 24 in.
RMP PVC Weight 2.75 lbs./ft.
Dia. 10 in. to 103 ft. depth Wall Thickness: inches or
Dia. in. to ft. depth gage No. 285

10. Screen: Manufacturer's name Pumped
Type PVC Dia. 5"
Slot/gauze 030 Length 20'
Set between 82 ft. and 102 ft.
Gravel pack? Size range of material 1/8 x 1/4

11. Static water level: 60 ft. below land surface Date 1-27-77

12. Pumping level below land surfaces: Air Test
 ft. after hrs. pumping g.p.m.
Estimated maximum yield 30 gpm g.p.m.

13. Water sample submitted: mo./day/yr.
Yes No Date

14. Well head completion: Capped
 Pitless adapter 24 Inches above grade

15. Well grouted?
With: Neat cement Bentonite Concrete
Depth: From 5 ft. to 15 ft.

16. Nearest source of possible contamination:
ft. 150 Direction South Type lots
Well disinfected upon completion? Yes No

17. Pump: Not installed
Manufacturer's name HP Volts
Length of drop pipe ft. capacity g.p.m.
Type: Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation: 1085
Topography: Hill Slope Upland Valley

19. Remarks: owner will pour cement slab

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Strader Dely Co Inc 192
Business name License No.
Address RT1 Holton, KS
Signed Dale Gishner Date 1-26-77
Authorized representative

S
R
L
S
W
L
NE
NW
E
W
1/4
1/4
1/4
1/4

ENVIRONMENTAL HEALTH LABORATORY

REPORTED

Results of Special Chemical Analyses

City Jackson County Shipper Dwight Brinkley Acct. Oil Field Lab. No. 77-894

Date Received 1-31-77

Date Reported FEB 10 1977 Bottle No. _____
Copy to: Dwight Brinkley

SOURCE AND REMARKS:

Bill Hanzlicek, Netawaka. New test hole west of new home. ^{NE}~~NW~~, NW, NW Sec 11-5-15E.
collected 1-31-77.

RESULTS EXPRESSED IN MILLIGRAMS PER LITER

Sp Cond	pH	Boron
Total Solids	Turbidity	Copper
T H (CaCO ₃) ✓ 1670.	Diss Oxygen	Lead
Calcium (Ca) ✓ 414.	5 day 20°C BOD	Zinc
Magnesium (Mg) ✓ 156.	Chem Oxy Demand	Hex Chromium
Sodium ✓ 230.	Phosphate (PO ₄)	Cadmium
Potassium	Ammonia (N)	Silver
Alk (CaCO ₃) ✓ 306.	Nitrite (N)	Mercury
Chloride ✓ 73.	Total Org N	Arsenic
Sulfate ✓ 1690.	Detergent (LAS)	
Nitrate (NO ₃) ✓ 0.1	T Susp Solids	
Fluoride ✓ 0.7	F Susp Solids	
Total Iron ✓ 4.6	V Susp Solids	
Manganese ✓ 0.51	Silica (SiO ₂)	