

35

P.P.T

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

well #2 ^{CDP} south north

1. Location of well: County Atchison Brown		Fraction NE SE SW SW 1/4 SW 1/4 SW 1/4		Section number 6	Township number T 5 S	Range number R 18 E/W
2. Distance and direction from nearest town or city: 4.5 E SS			3. Owner of well: Horton City Well #2			
Street address of well location if in city: OF HORTON			R.R. or street: City, state, zip code: HORTON, Kans. 66439			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 24 in. Completion date 7-18-79 Well depth 71 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		0	3	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 36 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 38.55 lbs./ft. Dia. 12 in. to 71 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 375		
Clay, brown		3	27	10. Screen: Manufacturer's name JOHNSON STAINLESS STEEL Type STAINLESS STEEL Dia. 12 Slit/gauze .025 Length 10 Set between 61 ft. and 71 ft. ft. and <input type="checkbox"/> ft.		
Fine sand		27	32	Gravel pack? <input checked="" type="checkbox"/> Size range of material #30x.060		
Clay, blue		32	49	11. Static water level: <input type="checkbox"/> mo./day/yr. 26 ft. below land surface Date 7-18-79		
Fine sand, yellow, clean, water bearing		49	71	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield +70 110 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 7-31-79		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 36 Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 25 ft.		
				16. Nearest source of possible contamination: ft. 200 Direction W Type LAKE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name JACUZZI Model number 556m HP 5 Volts 230 Length of drop pipe 63 ft. capacity 100 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 1060		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER DRILG CO INC R2 Business name License No. Address RT1 Horton, KS Signed Dale Astrom Date 7-19-79 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		slab will be installed 6x6x6				

T
R
W
SW
1/4
1/4
1/4
1/4