USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Marshall	~~NW~~ 1/4 SE 1/4 SE 1/4	25	T 5 S	R 6 E/~~W~~

2. Distance and direction from nearest town or city: 6 S-1½W-¾S of Blue Rapids Ks
Street address of well location if in city:

3. Owner of well: Marie Musel
R.R. or street:
City, state, zip code: Blue Rapids Ks 66411

4. Locate with "X" in section below: Sketch map:

N
NW | NE
W | E
SW | SE X
S
1 Mile ← → 1 Mile

Clean out old Well + Recase

5. Type and color of material Est. of Log	From	To
Dirt Black	0	5
Clay Brown	5	26
Lime Rock White	26	30
Clay Brown	30	45
Lime Rock White	45	50
Clay Brown	50	60
Lime Rock White	60	65
Clay Yellow	65	75
Lime Rock White + Flint Blue	75	85
Shale Brown	85	95
" Blue	95	97

(Use a second sheet if needed)

6. Bore hole dia. 8 in. Completion date
Well depth 97 ft. Aug. 22-79

7. X Cable tool ___ Rotary ___ Driven ___ Dug
___ Hollow rod ___ Jetted ___ Bored ___ Reverse rotary

8. Use: ___ Domestic ___ Public supply ___ Industry
___ Irrigation ___ Air conditioning X Stock
___ Lawn ___ Oil field water ___ Other

9. Casing: Material Pvc Height: Above or below
Threaded ___ Welded None Surface 12 in.
RMP ___ PVC X Weight ___ lbs./ft.
Dia. 5 in. to 97 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. Sch. 40

10. Screen: Manufacturer's name Pumpco
Type PVC Dia. 5"
Slot/gauze ½ Length 20'
Set between 76 ft. and 97 ft.
___ ft. and ___ ft.
Gravel pack? Yes Size range of material ⅛-½

11. Static water level: mo./day/yr.
60 ft. below land surface Date 8-22-79

12. Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

13. Water sample submitted: mo./day/yr.
___ Yes X No Date

14. Well head completion:
___ Pitless adapter ___ Inches above grade

15. Well grouted? Yes
With: X Neat cement ___ Bentonite ___ Concrete
Depth: From 5 ft. to 15 ft.

16. Nearest source of possible contamination:
ft. 100 Direction W Type Barn
Well disinfected upon completion? X Yes ___ No

17. Pump: X Not installed
Manufacturer's name
Model number ___ HP ___ Volts ___
Length of drop pipe ___ ft. capacity ___ g.p.m.
Type:
___ Submersible ___ Turbine
___ Jet ___ Reciprocating
___ Centrifugal ___ Other

18. Elevation:

Topography:
___ Hill
___ Slope
X Upland
___ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Harpers Drlg Serv 176
Business name License No.
Address Blue Rapids Ks 66411
Signed [signature] Date 8-22-79
Authorized representative

T 5 — R 6 E/W — Sec 25 — 1/4 1/4 1/4 NW SE SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

M1-1023