

LOCATION OF WATER WELL	Fraction	Section Number	Township Number	Range Number
County: <u>CLAY</u>	<u>NE 1/4 NE 1/4 NE 1/4</u>	<u>2</u>	<u>T 6 S</u>	<u>R 1 E</u>
Distance and direction from nearest town or city? <u>IN CLIFTON</u>		Street address of well if located within city?		
WATER WELL OWNER: <u>DAVID TOTTEN</u>				
R#, St. Address, Box #			Board of Agriculture, Division of Water Resources	
City, State, ZIP Code: <u>CLIFTON, KANSAS 66937</u>			Application Number:	
DEPTH OF COMPLETED WELL: <u>80</u> ft. Bore Hole Diameter: <u>8</u> in. to <u>80</u> ft., and <u>80</u> in. to <u>80</u> ft.				
Well Water to be used as:				
<input checked="" type="checkbox"/> 1 Domestic <input type="checkbox"/> 3 Feedlot <input type="checkbox"/> 6 Oil field water supply <input type="checkbox"/> 9 Dewatering <input type="checkbox"/> 11 Injection well <input type="checkbox"/> 2 Irrigation <input type="checkbox"/> 4 Industrial <input type="checkbox"/> 7 Lawn and garden only <input type="checkbox"/> 10 Observation well <input type="checkbox"/> 12 Other (Specify below)				
Well's static water level: <u>60</u> ft. below land surface measured on <u>2</u> month <u>27</u> day <u>1981</u> year				
Pump Test Data: Well water was <u>15</u> gpm: Well water was <u>15</u> ft. after <u>15</u> hours pumping <u>15</u> gpm				
TYPE OF BLANK CASING USED:				
<input checked="" type="checkbox"/> 1 Steel <input type="checkbox"/> 3 RMP (SR) <input type="checkbox"/> 6 Asbestos-Cement <input type="checkbox"/> 9 Other (specify below)    Casing Joints: Glued <input checked="" type="checkbox"/> Clamped <input type="checkbox"/> <input checked="" type="checkbox"/> 2 PVC <input type="checkbox"/> 4 ABS <input type="checkbox"/> 7 Fiberglass <input type="checkbox"/> 8 Concrete tile    Welded <input type="checkbox"/> <input type="checkbox"/> 5 Wrought iron    Threaded <input type="checkbox"/>				
Blank casing dia: <u>5</u> in. to <u>60</u> ft., Dia <u>5</u> in. to <u>60</u> ft., Dia <u>5</u> in. to <u>60</u> ft.				
Casing height above land surface: <u>12</u> in., weight <u>3</u> lbs./ft. Wall thickness or gauge No. <u>1258</u>				
TYPE OF SCREEN OR PERFORATION MATERIAL:				
<input type="checkbox"/> 1 Steel <input type="checkbox"/> 3 Stainless steel <input type="checkbox"/> 5 Fiberglass <input checked="" type="checkbox"/> 7 PVC <input type="checkbox"/> 10 Asbestos-cement <input type="checkbox"/> 2 Brass <input type="checkbox"/> 4 Galvanized steel <input type="checkbox"/> 6 Concrete tile <input type="checkbox"/> 8 RMP (SR) <input type="checkbox"/> 11 Other (specify) <input type="checkbox"/> 3 Screen or Perforation Openings Are: <input type="checkbox"/> 5 Gauzed wrapped <input checked="" type="checkbox"/> 8 Saw cut <input type="checkbox"/> 11 None (open hole)				
<input type="checkbox"/> 1 Continuous slot <input type="checkbox"/> 3 Mill slot <input type="checkbox"/> 6 Wire wrapped <input type="checkbox"/> 9 Drilled holes <input type="checkbox"/> 2 Louvered shutter <input type="checkbox"/> 4 Key punched <input type="checkbox"/> 7 Torch cut <input type="checkbox"/> 10 Other (specify)				
Screen-Perforation Dia: <u>5</u> in. to <u>80</u> ft., Dia <u>5</u> in. to <u>80</u> ft., Dia <u>5</u> in. to <u>80</u> ft.				
Screen-Perforated Intervals: From <u>60</u> ft. to <u>80</u> ft., From <u>60</u> ft. to <u>80</u> ft., From <u>60</u> ft. to <u>80</u> ft.				
Gravel Pack Intervals: From <u>14</u> ft. to <u>80</u> ft., From <u>14</u> ft. to <u>80</u> ft., From <u>14</u> ft. to <u>80</u> ft.				
GROUT MATERIAL: <input checked="" type="checkbox"/> 1 Neat cement <input type="checkbox"/> 2 Cement grout <input type="checkbox"/> 3 Bentonite <input type="checkbox"/> 4 Other				
Grouted Intervals: From <u>4</u> ft. to <u>14</u> ft., From <u>4</u> ft. to <u>14</u> ft., From <u>4</u> ft. to <u>14</u> ft.				
What is the nearest source of possible contamination:				
<input type="checkbox"/> 1 Septic tank <input type="checkbox"/> 4 Cess pool <input type="checkbox"/> 7 Sewage lagoon <input type="checkbox"/> 10 Fuel storage <input type="checkbox"/> 14 Abandoned water well <input type="checkbox"/> 2 Sewer lines <input type="checkbox"/> 5 Seepage pit <input type="checkbox"/> 8 Feed yard <input type="checkbox"/> 11 Fertilizer storage <input type="checkbox"/> 15 Oil well/Gas well <input type="checkbox"/> 3 Lateral lines <input type="checkbox"/> 6 Pit privy <input type="checkbox"/> 9 Livestock pens <input checked="" type="checkbox"/> 12 Insecticide storage <input type="checkbox"/> 16 Other (specify below) <input type="checkbox"/> 13 Watertight sewer lines				
Direction from well: <u>WEST</u> How many feet: <u>25</u> ? Water Well Disinfected? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>				
Has a chemical/bacteriological sample submitted to Department? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If yes, date sample as submitted: month <u>  </u> day <u>  </u> year: Pump Installed? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>				
Yes: Pump Manufacturer's name: <u>JACUZZI</u> Model No. <u>554B</u> HP <u>1/2</u> Volts <u>230</u>				
Depth of Pump Intake: <u>75</u> ft. Pumps Capacity rated at <u>10-12</u> gal./min.				
Type of pump: <input checked="" type="checkbox"/> 1 Submersible <input type="checkbox"/> 2 Turbine <input type="checkbox"/> 3 Jet <input type="checkbox"/> 4 Centrifugal <input type="checkbox"/> 5 Reciprocating <input type="checkbox"/> 6 Other				
CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on <u>2</u> month <u>27</u> day <u>1981</u> year				
And this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>359</u>				
His Water Well Record was completed on <u>3</u> month <u>25</u> day <u>1981</u> year under the business name of <u>DARYL Cox + SONS INC</u> by (signature) <u>Daryl Cox</u>				
LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		LITHOLOGIC LOG		
		FROM	TO	LITHOLOGIC LOG
		0	3	TOPSOIL
		3	10	BROWN CLAY
		10	15	SANDROCK
		15	45	RED CLAY
		45	60	SANDY CLAY
		60	71	SANDROCK GRAVEL
		71	80	GRAY CLAY
ELEVATION: <u>1300</u>		LITHOLOGIC LOG		
Depth(s) Groundwater Encountered 1. <u>  </u> ft. 2. <u>  </u> ft. 3. <u>  </u> ft. 4. <u>  </u> ft. (Use a second sheet if needed)				