

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County CLAY	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 14	Township number T 6 S R 1 EW	Range number
2. Distance and direction from nearest town or city:	2 S of CLIFTON		3. Owner of well: ED MEENEN R.R. or street: RR # 3 City, state, zip code: CLIFTON, KANSAS		
4. Locate with "X" in section below:	Sketch map: N W E S 1 Mile		6. Bore hole dia. 30 in. Completion date 9/27/75 Well depth 68 ft.		
5. Type and color of material	From	To	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Top soil + CLAY	0	23	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
SAND	23	28	9. Casing: Material AC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34 lbs./ft. Dia. 16 in. to 68 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 34		
SAND + GRAVEL	28	32	10. Screen: Manufacturer's name JOHNSON CONCRETE Type TRANSITE Dia. 16 Slot/gauze 1/2 Length 26 Set between 42 ft. and 68 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 1/4" - 1/2"		
GRAVEL	32	39	11. Static water level: <input type="checkbox"/> mo./day/yr. 30 ft. below land surface. Date 9/27/75		
SAND	39	41	12. Pumping level below land surfaces: 49 ft. after 1/2 hrs. pumping 1150 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 2000 g.p.m.		
GRAVEL	41	46	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Big GRAVEL	46	64	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
SAND + GRAVEL	64	68	15. Well grouted? NO With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft.		
SOFT BROWN CLAY	68	72	16. Nearest source of possible contamination: ft. 600 Direction N Type RIVER Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
FINE SAND	72	82	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name WLR Model number 8M HP 40 Volts <input type="checkbox"/> Length of drop pipe 53 ft. capacity 1500 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
SHALE	82		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. GEO COX & SONS, INC 258 Business name License No. Address CLIFTON KANSAS Signed James W Date 11-28 Authorized representative		
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5