

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ada

1. Location of well:		County Jackson	Fraction NE 1/4 SE 1/4 NE 1/4	Section number 33	Township number T 6 S R 14 E W	Range number
2. Distance and direction from nearest town or city: 1 1/2 S Street address of well location if in city: Circleville			3. Owner of well: Gene George R.R. or street: Box 276 City, state, zip code: Circleville, Kans			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8' in. Completion date _____ Well depth 142 ft. 6-19-77		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Top Soil				0	1	9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP PVC One Weight 2.74 lbs./ft. Dia. 5 in. to 142 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 258
Brown Clay				1	25	10. Screen: Manufacturer's name Pump Co Type PVC Dia. 5" Slot/gauze 022 Length 20 Set between 127 ft. and 142 ft. ft. and _____ ft.
Gray Clay				25	82	Gravel pack? yes Size range of material 0.30/0.80
Gray Gravelly Clay				82	86	11. Static water level: _____ mo./day/yr. 80 ft. below land surface Date 6-14-77
Gray Clay				86	114	12. Pumping level below land surfaces: Air Test _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.
Gray-White coarse sand to med gravel				114	142	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
						14. Well head completion: Top Cap <input type="checkbox"/> Pitless adapter 24 Inches above grade
						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.
						16. Nearest source of possible contamination: #19 ft. _____ Direction _____ Type _____ Well disinfected upon completion? yes Yes <input type="checkbox"/> No <input type="checkbox"/>
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
1175 (Use a second sheet if needed)						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Dely Co Inc #12 Business name _____ License No. _____ Address RT1 Holton, KS Signed Dale Rubin Date 6-19-77 Authorized representative
18. Elevation: 1070		19. Remarks: owner will construct cement slab around well #16 well in pasture				
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

20 56 11 70

6 24 W 33 NE SE NE