

USE TYPEWRITER OR BALL
POINT PEN-PRINT
PRINT CLEARLY

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County ATCHISON		Fraction NW NE 1/4 NE 1/4	Section number 19	Township number T 6 S	Range number R 18 W
2. Distance and direction from nearest town or city: 2 W Street address of well location if in city: OF EFFINGHAM			3. Owner of well: ANDY ECKERT R.R. or street: City, state, zip code: EFFINGHAM		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 10 in. Completion date 3-3-77 Well depth 140 ft.		
5. Type and color of material			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 34 in. RMP PVC 94 Weight 2.50 lbs./ft. Dia. 5 in. to 140 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 3.29		
			10. Screen: Manufacturer's name PUMPGO Type PVC Dia. 5 <input checked="" type="checkbox"/> Slot gauge .020 Length 20 Set between 110 ft. and 130 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material .030 x .060		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 100 ft. below land surface Date 3-3-77		
			12. Pumping level below land surfaces: AIR 25 T ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 6 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 24 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.		
			16. Nearest source of possible contamination: ft. 100 Direction E Type LOTS Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 1240 Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: OWNER WILL INSTAL SLAB		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STEADER DILLING CO INC 182 Business name License No. Address RR #1 HOLTON KS Signed Jim Johnson Date 3-5-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5