



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

6/19/23
T R EW sec 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

NE SW NW BCA

1 Location of well:	County Atchison	Township name Center	Fraction NE 1/4 - NW 1/4	Section number 23	Town number 65	Range number 19E
Distance and direction from nearest town or city: 3 mi. E Farmington			3 Owner of well: Bud Hulings Address: RFD Atchison, Ks.			
Locate with "X" in section below: N  W S 1 Mile		Sketch map:  N 600'		4 Well depth: 100 ft. Date of completion 7-8-75 Well diameter 10 in.		
2 Type and color of material		From		To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well
						7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. Diam. Weight 2.33 lbs./ft. 0 in. to 100 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to in. ft. depth
						8 Screen: Manufacturer Pump Co Type PVC Dia. 5" Slot .025 Length 10 Set between 20 ft. and 100 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material #3
						9 Static water level: NOT MEASURED ft. below land surface Date
				10 Pumping level below land surfaces: AIR TEST ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 10 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: CAPPED <input type="checkbox"/> Pitless adapter 24" inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: ft. 100 Direction N. W Type S. Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation 1205' Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Stader Drilling Co Inc 182 Business name License No. Address RFD 1 Holton, Kans 66436 Signed Bob Stader Date 7-9-75 Authorized representative		