

LOCATION OF WATER WELL	Fraction <u>SW SE SE</u> <u>1/4 SW 1/4 SE</u>	Section Number <u>29</u>	Township Number <u>T 6 S</u>	Range Number <u>R 2 E E/W</u>
------------------------	--	-----------------------------	---------------------------------	----------------------------------

Distance and direction from nearest town or city? 5 South - 2 East of Clifton Street address of well if located within city?

WATER WELL OWNER: Mark Taddiken
 R#, St. Address, Box #: Route # 1
 City, State, ZIP Code: Clifton, Kansas 66937
 Board of Agriculture, Division of Water Resources
 Application Number:

DEPTH OF COMPLETED WELL: 50 ft. Bore Hole Diameter: 8 in. to 50 ft. and in. to ft.

Well Water to be used as:

<input type="checkbox"/> 1 Domestic	<input type="checkbox"/> 3 Feedlot	<input type="checkbox"/> 6 Oil field water supply	<input type="checkbox"/> 9 Dewatering	<input type="checkbox"/> 11 Injection well
<input type="checkbox"/> 2 Irrigation	<input type="checkbox"/> 4 Industrial	<input type="checkbox"/> 7 Lawn and garden only	<input type="checkbox"/> 10 Observation well	<input type="checkbox"/> 12 Other (Specify below)

Well's static water level: 24 ft. below land surface measured on 11 month 3 day 1980 year
 Pump Test Data: Well water was 35 ft. after 1/2 hours pumping 50 gpm
 Test Yield 1.00 gpm: Well water was ft. after hours pumping gpm

TYPE OF BLANK CASING USED:

<input type="checkbox"/> 1 Steel	<input type="checkbox"/> 3 RMP (SR)	<input type="checkbox"/> 6 Asbestos-Cement	<input type="checkbox"/> 9 Other (specify below)	Casing Joints: <input checked="" type="checkbox"/> Glued <input type="checkbox"/> Clamped
<input checked="" type="checkbox"/> 2 PVC	<input type="checkbox"/> 4 ABS	<input type="checkbox"/> 7 Fiberglass		<input type="checkbox"/> Welded
				<input type="checkbox"/> Threaded

Blank casing dia: 5 in. to 40 ft. Dia in. to ft. Dia in. to ft.
 Casing height above land surface: 12 in., weight 3 lbs./ft. Wall thickness 0.258 in.

TYPE OF SCREEN OR PERFORATION MATERIAL:

<input type="checkbox"/> 1 Steel	<input type="checkbox"/> 3 Stainless steel	<input type="checkbox"/> 5 Fiberglass	<input checked="" type="checkbox"/> 7 PVC	<input type="checkbox"/> 10 Asbestos-cement
<input type="checkbox"/> 2 Brass	<input type="checkbox"/> 4 Galvanized steel	<input type="checkbox"/> 6 Concrete tile	<input type="checkbox"/> 8 RMP (SR)	<input type="checkbox"/> 11 Other (specify)
			<input type="checkbox"/> 9 ABS	<input type="checkbox"/> 12 None used (open hole)

Screen or Perforation Openings Are:

<input type="checkbox"/> 1 Continuous slot	<input type="checkbox"/> 3 Mill slot	<input type="checkbox"/> 5 Gauzed wrapped	<input checked="" type="checkbox"/> 8 Saw cut	<input type="checkbox"/> 11 None (open hole)
<input type="checkbox"/> 2 Louvered shutter	<input type="checkbox"/> 4 Key punched	<input type="checkbox"/> 6 Wire wrapped	<input type="checkbox"/> 9 Drilled holes	
		<input type="checkbox"/> 7 Torch cut	<input type="checkbox"/> 10 Other (specify)	

Screen-Perforation Dia: 5 in. to ft. Dia in. to ft. Dia in. to ft.
 Screen-Perforated Intervals: From 40 ft. to 50 ft. From ft. to ft. From ft. to ft.
 Travel Pack Intervals: From 10 ft. to 50 ft. From ft. to ft. From ft. to ft.

GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. From ft. to ft.


What is the nearest source of possible contamination: None

<input type="checkbox"/> 1 Septic tank	<input type="checkbox"/> 4 Cess pool	<input type="checkbox"/> 7 Sewage lagoon	<input type="checkbox"/> 11 Fertilizer storage	<input type="checkbox"/> 14 Abandoned water well
<input type="checkbox"/> 2 Sewer lines	<input type="checkbox"/> 5 Seepage pit	<input type="checkbox"/> 8 Feed yard	<input type="checkbox"/> 12 Insecticide storage	<input type="checkbox"/> 15 Oil well/Gas well
<input type="checkbox"/> 3 Lateral lines	<input type="checkbox"/> 6 Pit privy	<input type="checkbox"/> 9 Livestock pens	<input type="checkbox"/> 13 Watertight sewer lines	<input type="checkbox"/> 16 Other (specify below)

Direction from well: How many feet? ? Water Well Disinfected? Yes No
 Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample submitted month day year
 Pump Installed? Yes No
 Yes: Pump Manufacturer's name Model No. HP Volts
 Depth of Pump Intake ft. Pumps Capacity rated at gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on November month 3 day 1980 year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 361
 This Water Well Record was completed on November month 7 day 1980 year under the business name of Cox - Beswick Irrigation Service, Inc. by (signature) Francis Cox

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
		0	31	Top soil & clay		
	31	34	Brown gravel			
	34	48	Good green gravel			
	48	50	Gravel & clay			
	50		Fine sand			



ELEVATION: Depth(s) Groundwater Encountered 1. 31 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.