WATER WELL RECORD KSA 820-1201-1215 AFD A

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section	number	Township number	Range number	
1. Location of well:	Atchison	NE 1/4SE 1/4 NE	1/4	2	28	т 6S s	R 21E DW	
					ner of well: Harold Rice & John Hertsog			
2½ East of Atchison, Ks. Street address of well location if in city: City. sta					reet: Box 328 re, z m code: Lees Summit, Mo. 64063		64063	
4. Locate with "X" in section below: Sketch map:					6 Bore hole dia		. Completion date 6-8-77	
N A A A A A A A A A A A A A A A A A A A				3/		Well depth 91 ft.		
E SW SE - SE				5504 K1 K14		7 Cable tool Rotary	Driven Dug Bored X Reverse rotary	
						8. Use: Domestic Po		
						X Irrigation Air conditioning Stock tawn Oil field water Other 9. Casing: Material Trans Height: Above or below Threaded Welded Surface 12 in. RMP PVC Weight lbs./ft. Dia.16 in. to 59 ft. depth Wall Thickness: inches or		
								•
5. Type and color of material				From	T _o T	Dia in. to ft. dep	th gage No75"	
				ļ		To. Screen: Manufacturer's r Johnson Well		
Hard br	cown soil			0	1	Type Transite	_ Dia16"	
Hard black soil			1	3	Set between	Length 39 91 ft.		
				3	8	ft	andft.	
nard bi	rown silty soil			-	0	Gravel pack?	mo./day/yr.	
Small gray gravel			8	30	ft. below land sur			
Large gray gravel			30	34	12. Pumping level below land	d surfaces:		
			34 469	49	14 ft. after 1 hrs. pumping 1000 g.p.m. 1500 g.p.m. 1500 g.p.m.			
Small gray gravel					Estimated maximum yield			
Small gray gravel & gray clay			49	51	13. Water sample submitted: YesX_ No	mo./day/yr.		
Small to med. gray gravel			51	52	14. Well head completion:			
Large gray gravel			52	58	Pitless adapter 15. Well grouted?	Inches above grade		
			T		With: Neat cement	Bentonite X Concrete	_	
Large gray gravel & gray clay				58	65	Depth: From O ft. to		0
Med. to large gray gravel &				65	91		uth Type creek	
Stopped.			91			etion? Yes X No	N	
						17. Pump: Manufacturer's name	X Not installed	" <u> </u>
						Model number	HP Volts	, ≥ ⊝
						Length of drop pipe	ft. capacityg.p.m.	- (
						Submersible Jet	Turbine Reciprocating	IN
	(Use a second s	heet if needed)				Centrifugal	Other	S 1.
18. Elevation: 19. Remarks:					20. Water well contractor's	certification: ny jurisdiction and this report	P	
We do not install pumps.					is true to the best of my know	wledge and belief.	4	
Topography:					Hoobler Drillin	/ License No	211	
Slope						Address St. Marys,	Ks. 66536	مات
X Valley	Upland X Valley					Signed Authorized rep	Date 7-6-7	2 2
- variey							E MANC &	á,