

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>CLAY</b>	Fraction <b>NE 1/4 NE 1/4 NE 1/4</b>	Section number <b>25</b>	Township number <b>T 6 S R 3 E</b>	Range number <b>3 E</b>
2. Distance and direction from nearest town or city: <b>4 E - 9 N</b> Street address of well location if in city: <b>CLAY CENTER</b>			3. Owner of well: <b>DARWIN MALL</b> R.R. or street: <b>R ROUTE</b> City, state, zip code: <b>GREEN, KANS 67447</b>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>8</b> in. Completion date <b>4-10-79</b> Well depth <b>34</b> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <b>PVC</b> Height <b>Above</b> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <b>3</b> lbs./ft. Dia. <b>5</b> in. to <b>24</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <b>258</b>		
				10. Screen: Manufacturer's name <b>PUMPED</b> Type <b>PVC</b> Dia. <b>5</b> Slot/gauze <b>1/16</b> Length <b>20</b> Set between <b>14</b> ft. and <b>34</b> ft. Gravel pack? <b>YES</b> Size range of material <b>20x14</b>		
				11. Static water level: _____ mo./day/yr. <b>4</b> ft. below land surface Date <b>4-10-79</b>		
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after <b>NH</b> hrs. pumping _____ g.p.m. Estimated maximum yield <b>5</b> g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> Inches above grade		
				15. Well grouted? <b>YES</b> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
				16. Nearest source of possible contamination: <b>HOG</b> ft. <b>200</b> Direction <b>SOUTH</b> Type <b>FLOOR</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>DARYL COX + SONS INC 359</b> Business name License No. Address <b>241-10N KANS 66937</b> Signed <b>Daryl Cox</b> Date <b>5-10-79</b> Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

6-3-79  
W  
25  
NE NE NE  
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5