

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County CLAY	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 20	Township number T 6 S R	Range number 4 EW
2. Distance and direction from nearest town or city: 1/2 S - 6 1/2 E			3. Owner of well: GRANT SUMP			
Street address of well location if in city: GARFIELD CENTER			R.R. or street: RT			
			City, state, zip code: GREEN KANS 67447			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 10-20-78		
		5 1/2 NORTH 1/4 WEST GREEN		Well depth 44 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 48 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 44 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1258		
5. Type and color of material				From	To	10. Screen: Manufacturer's name PUMPRO
TOPSOIL				0	3	Type PVC Dia. 5"
BROWN CLAY				3	10	Slot/gauze 1/16 Length 44 ft.
LIMESTONE CREEK GRAVEL				10	22	Set between 24 ft. and 44 ft.
BLUE CLAY				22	37	Gravel pack? YES Size range of material 1/4 x 1/4
LIMESTONE GRAVEL				37	41	11. Static water level: 15 ft. below land surface Date 10-20-78
GYPSUM				41	44	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after N/A pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after N/A hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 20 g.p.m.
STOP				44		13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 10-20-78
						14. Well head completion: <input type="checkbox"/> Pitless adapter 48 Inches above grade
						15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: ft. 50 Direction SOUTH Type CREEK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PHYLL COX & SONS INC. 359 Business name License No. _____ Address CLIFTON KANS 66937 Signed Phyll Cox Date 10-30-78 Authorized representative
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

T 6
R 40
W 20
SW SE
1/4 1/4 1/4