

SRV-1-7-77

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY. PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County CLAY		Fraction SW 1/4 SE 1/4 SE 1/4		Section number 21	Township number T 7 S R 1	Range number EW
2. Distance and direction from nearest town or city: 11 SOUTH 3 WEST CLIFTON				3. Owner of well: ARLAN CLOSE R.R. or street: MILTON VALE City, state, zip code: CLAY CENTER KANSAS 64432		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 3/25/76 Well depth 157 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
TOPSOIL		0	2	9. Casing: Material PVC Height (Above or below) 18 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 157 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 1214		
BROWN CLAY		2	11	10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5 Slot/gauze 1/16 Length 40 Set between 157 ft. and 137 ft. 97 ft. and 77 ft. Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 1/8 x 1/4		
SANDROCK		11	15	11. Static water level: 20 ft. below land surface Date 3/25/76 mo./day/yr.		
GRAY CLAY		15	21	12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after NA hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 3 g.p.m.		
BROWN CLAY		21	31	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____ mo./day/yr.		
GRAY CLAY		31	81	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
SANDROCK W/CLAY		81	91	15. Well grouted? <input checked="" type="checkbox"/> YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. MHC		
GRAY CLAY		91	101	16. Nearest source of possible contamination: 200 ft. Direction EAST Type LOTS Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
HARD ROCK		101	102	17. Pump: <input checked="" type="checkbox"/> Nat installed Manufacturer's name _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
BLUE SHALE		102	200			
STOP		200				
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. GEO COX + SONS INC 58 Business name License No. _____ Address CLIFTON KANSAS 64437 Signed Daryl Cox Date 3/25/76 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

- 2 -
R
W
2
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5