USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	Section number		Township number	Range number	
1011 HW1/401 W 1/4 01 W 1/4	<u> </u>	2	T / S	R 10	E.(W)
2. Distance and direction from nearest rown of city: 3 E, 23. R.R. or street: RR.					
City, side, 219 code: Plat 112 100 110					
Locate with "X" in section below: Sketch map:			6. Bore hole dia. 5 in. Completion date 2-11-76 Well depth 6.		
			7. Z Cable tool Rotary Driven Dug		
			8. Use: X Domestic Public supply Industry		
₩			Irrigation Air conditioning Stock		
SW SE			LawnOil field water Other 9. Casing: Material (ST Height: Above or below		
			Threaded Welded in.		
S 11 Mile			PVC Weight lbs./ft. Dia. 5 in. to 80 ft. depth Wall Thickness: inches or		
5. Type and color of material	From	То	Dia in. to ft. dept 10. Screen: Manufacturer's n		20
Brown Clau	0	15	SISTES !	3y prill	612
Charles Comment	15	20	Slot/gauze //6	_ Dia	
Cler Grave			Set betweenft. c		2ft.
Lime Rock	20	25	Gravel pack? Size ra	7	-/-
White Clay	25	30	11. Static water level:ft. below land sur		1-67
Blue Shale	30	35	12. Pumping level below land		g.p.m.
Green Clav	35	40	ft. after		g.p.m.
Vellow Lime Rock	40	45	Estimated maximum yield —— 13. Water sample submitted:	m	o./day/yr.
11 11 11	45	50	Yes No	Date	
Play	50	55	X Pitless adapter	Inches abov	e grade
Con Control Cham		10	15. Well grouted? VES With: Neat coment	Bentonite	Concrete
Gray Sandy Clay	55	60	Depth: Fromft. to		
Brown	60	65	16. Nearest source of possible ft. 500 Direction	contamination:	tek Pars
11 SHZ/e	65	10	Well disinfected upon comple	Yes Yes Not installed	No
ft it	70	75	Manufacturer's name		N
B/ye "	75	80	Model number	HP V ft. capacity	_g.p.m. 6
			Type: Submersible	Turbi	ine
(Use a second sheet in needed)			Jet Centrifugal	Recip	procating
18. Elevation: 19. Remarks:	1	1	20. Water well contractor's	certification:	
Coment Slab to be Installed			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography: HIII X Slope Upland Dement Slab to be anstalled Ly Land owner His agreement			Jahren rage 176 Elicense No.		
X Slope Ifis agreement			Address Sugardons.		
UplandValley	Signed Authorized App	respitative Da	<u></u>		
Form WWC-5					