

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

SUNNYSIDE WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County Pottawatomie Fraction NE 1/4 NW 1/4 Section number 14 Township number 7 South Range number 10 east	
2. Distance and direction from nearest town or city: Westmoreland 2 1/2 mi north + 8 east 1/2 north on west side road 3. Owner of well: Wayne Buford R.R. or street: Wheaton Lane City, state, zip code:	
4. Locate with "X" in section below: Sketch map:	
6. Bore hole dia. 10 in. Completion date May 13-77 Well depth 247 ft.	
7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Drives <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material PVC Height: Above or Below Surface Threading: Welded Surface 40 in. RMP: PVC <input checked="" type="checkbox"/> Weight: 13 lbs./ft. Dia. 5 in. to 247 ft. depth Wall Thickness: inches or sch 40 Dia. 5 in. to 247 ft. depth gage No. sch 40	
5. Type and color of material	
	From To
top soil	0 5
Clay	5 12
Rock Limestone	12 30
Blue Shale	30 88
Rock Limestone	88 93
Blue Shale	93 150
Rock 7 livity	150 152
Blue Shale	152 247
10. Screen: Manufacturer's name Pumped Type PVC Dia. 5 1/2 in. Slot/gauze .040 Length 80 ft. Set between 12 ft. and 32 ft. 227 ft. and 247 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4" - 1/8"	
11. Static water level: 10 ft. below land surface Date 5-13-77 mo./day/yr.	
12. Pumping level below land surfaces: 2 1/2 g.p.m. Estimated maximum yield 2 1/2 g.p.m.	
13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 5-13-77 mo./day/yr.	
14. Well head completion: NA Pitless adapter NA inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 22 ft. to 12 ft.	
16. Nearest source of possible contamination: 60 ft. Direction West Type Creek Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: 1248 Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	
19. Remarks:	
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Shades Drilling Co 237 Business name License No. Address Blue Ridge Signed Harold Shades Date 5-13-77 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5