

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pott	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 17	Township number T 7 S R 10 E 4W	Range number
2. Distance and direction from nearest town or city: 3 1/2 mi. South of Wheaton Ks. Street address of well location if in city:				3. Owner of well: Julius Wahl R.R. or street: City, state, zip code: Wheaton Ks. 66551		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 9-23-77 Well depth 125 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Dirt Black		0	1	9. Casing: Material Plst Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 125 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. sch. 40		
loose lime Rock Clay White		1	5	10. Screen: Manufacturer's name slot by Driller Type pvc Dia. 5" Slot/gauze 1/64 Length 30' Set between 105 ft. and 125 ft. 105 ft. and 125 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/8 - 1/2		
Clay Brown		5	10	11. Static water level: _____ mo./day/yr. 54 ft. below land surface Date 9-23-77		
lime Rock White		10	13	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Clay White		13	34	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
Shale Blue		34	44	14. Well head completion: _____ Pitless adapter _____ Inches above grade		
lime Rock White		44	54	15. Well grouted? Yes Puddled Clay With: _____ Neat cement _____ Bentonite _____ Concrete Depth: From 0 ft. to 10 ft.		
Shale Gray		54	69	16. Nearest source of possible contamination: ft. 500 Direction SW Type Creek Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
lime Rock White		69	79	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Shale Blue		79	94			
lime Rock White		94	99			
Shale Blue		99	104			
lime Rock White		104	115			
Shale Blue		115	120			
" " + hard		120	125			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: Cement slab to be poured by land owner.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harper Dr. G. Serv. 176 Business name _____ License No. _____ Address Blue Rapids Ks Signed C. E. Harper Date 9-23-77 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 7 S R 10 E 4W
Sec 17 SW NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5