

V BRT

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

dcc

1. Location of well: County JACKSON Fraction SW 1/4 SW 1/4 SE 1/4 Section number 6 Township number T 7 R 13 Range number EW

2. Distance and direction from nearest town or city: 1 1/2 W. Street address of well location if in city: HOLTON, KS. 3. Owner of well: OTTO KUEHL R.R. or street: Box 85 City, state, zip code: ONAGA, KS. 66521

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 8 in. Completion date 7-16-76 Well depth 100 ft.

7. Cable tool Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry Irrigation Air conditioning Stock Lawn Oil field water Other Both

9. Casing: Material Threaded Welded Surface 24 in. RMP PVC Blue Weight 2.58 lbs./ft. Dia. 5 in. to 100 ft. depth Wall Thickness: inches or Dia. 5 in. to 100 ft. depth Page No. 274

10. Screen: Manufacturer's name Russco Type RVC Dia. 5 in. Slot/gauze .080 Length 20 ft. Set between 60 ft. and 80 ft. Gravel pack? Size range of material 1/4 x 1/4

11. Static water level: 50 ft. below land surface Date 7-16-76 mo./day/yr.

12. Pumping level below land surfaces: AIR TEST 20 ft. after 0 hrs. pumping 0 g.p.m. Estimated maximum yield 20 g.p.m.

13. Water sample submitted: No Date 7-16-76 mo./day/yr.

14. Well head completion: capped Pitless adapter 24 inches above grade

15. Well grouted? With: Neat cement Bentonite Concrete Depth: From 5 ft. to 15 ft.

16. Nearest source of possible contamination: ft. 300 Direction E Type lot Well disinfected upon completion? Yes No

17. Pump: Not installed Manufacturer's name Jacuzzi Model number 554B HP 1/2 Volts 230 Length of drop pipe 90 ft. capacity 10 g.p.m. Type: Submersible Turbine Jet Reciprocating Centrifugal Other

5. Type and color of material	From	To		From	To
Top Soil	0	2	Gr. Shale	56	57
Br. Clay	2	9	Rd. Shale	58	59
Br. Sandy Clay	9	22	BLK. Shale	59	65
Gray Clay	22	31	Gray L.S.	65	68
Gr. Lims. St.	31	32	Gray Shale	68	69
Br. L.S.	32	35	Gray L.S.	69	71
Br. Clay	35	37	Gray Shale	71	73
Gr. Clay	37	41	Gray L.S.	73	75
Gr. L.S.	41	45	Rd. Shale	75	78
Br. L.S.	45	46	Gray L.S.	78	80
Br. Shale	46	48	White L.S.	80	81
Gr. Shale	48	49	Gray L.S.	81	83
Red Shale	49	52	Gray Shale	83	89
Pink Shale	52	53	lt. Gray L.S.	89	92
Gr. Shale	53	55	Gray Shale	92	100
Rd. Shale	55	56			

18. Elevation: 1314 Topography: Hill Slope Upland Valley

19. Remarks: I will pour my own Cement Slab around the well
Otto Kuehl

20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name STADER Dalg Co Inc License No. 182 Address RT1 Holton, KS Signed Dale Gustafson Date 7-26-76 Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR = 1283

V = 1012