

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County <u>Jackson</u>		Fraction <u>NW 1/4 SW 1/4 NW 1/4</u>	Section number <u>25</u>	Township number <u>T 7 S R 13</u>	Range number <u>EW</u>
2. Distance and direction from nearest town or city: <u>10 W 3/4 S</u>			3. Owner of well: <u>Bob Kennedy</u>		
Street address of well location if in city: <u>Holtan</u>			R.R. or street: <u>RR</u>		
			City, state, zip code: <u>Sedalia Mo</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date <u>6-16-77</u>	
				Well depth <u>100</u> ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug	
				<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry	
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock	
				<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material <u>PVC</u> Height: <u>Above</u> or below	
<u>Brown Clay</u>		<u>0</u>	<u>13</u>	Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in.	
<u>Gray Shale</u>		<u>13</u>	<u>24</u>	RMP <input type="checkbox"/> PVC <u>Blue</u> Weight <u>2.74</u> lbs./ft.	
<u>Gray limestone</u>		<u>24</u>	<u>27</u>	Dia. <u>5</u> in. to <u>100</u> ft. depth Wall Thickness: inches or	
<u>Gray Shale</u>		<u>27</u>	<u>44</u>	Dia. <u>   </u> in. to <u>   </u> ft. depth gage No. <u>285</u>	
<u>Gray limestone</u>		<u>44</u>	<u>45</u>	10. Screen: Manufacturer's name <u>Pumpco</u>	
<u>Gray Shale</u>		<u>45</u>	<u>47</u>	Type <u>PVC</u> Dia. <u>5"</u>	
<u>Gray limestone w/Gyp</u>		<u>47</u>	<u>49</u>	Slot/gauze <u>080</u> Length <u>25</u>	
<u>Gray Shaley limestone</u>		<u>49</u>	<u>60</u>	Set between <u>45-55</u> ft. and <u>65-70</u> ft.	
<u>Brown Shale</u>		<u>60</u>	<u>64</u>	<u>85-95</u> ft. and <u>   </u> ft.	
<u>Gray Shale</u>		<u>64</u>	<u>69</u>	Gravel pack? <u>YES</u> Size range of material <u>1/4 x 1/8</u>	
<u>Brown Shale</u>		<u>69</u>	<u>70</u>	11. Static water level: <u>45</u> ft. below land surface Date <u>6-16-77</u>	
<u>Gray Shale</u>		<u>70</u>	<u>83</u>	12. Pumping level below land surfaces: <u>Air Test</u>	
<u>Gray limestone</u>		<u>83</u>	<u>88</u>	<u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m.	
<u>Light Gray limestone</u>		<u>88</u>	<u>91</u>	<u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m.	
<u>Gray limestone</u>		<u>91</u>	<u>94</u>	Estimated maximum yield <u>15</u> g.p.m.	
<u>Brown Shale</u> (Use a second sheet if needed)		<u>94</u>	<u>100</u>	13. Water sample submitted: <u>   </u> mo./day/yr.	
18. Elevation: <u>1110</u>	19. Remarks: <u>owner will construct cement slab around well</u>			14. Well head completion: <u>Cap Top</u>	
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	<u>#16 well is located in a pasture</u>			<input type="checkbox"/> Pitless adapter <u>24</u> inches above grade	
				15. Well grouted? <u>Yes</u>	
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete	
				Depth: From <u>0</u> ft. to <u>10</u> ft.	
				16. Nearest source of possible contamination: <u>#19 note</u>	
				ft. <u>   </u> Direction <u>   </u> Type <u>   </u>	
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed	
				Manufacturer's name <u>   </u>	
				Model number <u>   </u> HP <u>   </u> Volts <u>   </u>	
				Length of drop pipe <u>   </u> ft. capacity <u>   </u> g.p.m.	
				Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine	
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification:	
				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
				<u>Streater Poly Co Inc 182</u>	
				Business name <u>   </u> License No. <u>   </u>	
				Address <u>RT 1 Holtan, KS</u>	
				Signed <u>Walt Gibson</u> Date <u>6-17-77</u>	
				Authorized representative	

7 130 25 NW SW NW Sec 1/4 1/4 1/4